

BEFORE THE  
PUBLIC SERVICE COMMISSION OF WISCONSIN

Joint Application of Wisconsin Public Service )  
 Corporation and Wisconsin Electric Power )  
 Company for Authority to Construct the Weston ) Docket 5-CE-153  
 Reciprocating Internal Combustion Engine )  
 Project in the Villages of Rothschild and )  
 Kronenwetter, Marathon County, Wisconsin )

---

**DIRECT TESTIMONY OF JOHN MICHAEL HAGERTY  
 ON BEHALF OF WISCONSIN PUBLIC SERVICE CORPORATION AND  
 WISCONSIN ELECTRIC POWER COMPANY**

---

1 **Q. Please state your name, business address, and position.**

2 A. My name is John Michael Hagerty. My business address is 1800 M St Northwest,  
 3 Washington, DC 20036. My current position is Senior Associate for The Brattle Group  
 4 (“Brattle”).  
 5

6 **Q. Please describe your education and professional background.**

7 A. I received a M.S. in Technology and Policy from the Massachusetts Institute of  
 8 Technology and a B.S. in Chemical Engineering from the University of Notre Dame.

9 I have 10 years of experience in utility and electric power industry planning and  
 10 regulatory reviews, including studies of wholesale market design to achieve resource  
 11 adequacy requirements in MISO, studies on the cost of new entry (“CONE”) in PJM,  
 12 ISO-NE, and Alberta, Canada, utility resource planning in Arizona, Kansas, and North  
 13 Carolina, renewable energy resource economics and policy in numerous states, including  
 14 Nebraska, Illinois, Pennsylvania and California, transmission system upgrade needs in  
 15 MISO, SPP, ERCOT, CAISO, NYISO, and ISO-NE, and optimized approaches to

1 economy-wide deep decarbonization across the U.S. and specifically in California and  
2 New England.

3 Prior to joining Brattle, I was a research assistant at the MIT Energy Initiative  
4 focusing on renewable energy integration in the electric power sector and industrial uses  
5 of natural gas, a chemical process engineer at Honeywell advising the startup of new oil  
6 refinery process units in the U.S., Japan, Thailand, Vietnam and Saudi Arabia, and a  
7 research chemist at GE Global Research developing low emissions automotive coatings.

8  
9 **Q. Have you previously testified before the Wisconsin Commission?**

10 A. No, but I have testified before the Alberta Utility Commission concerning the costs of  
11 new gas-fired resources in the Alberta Electric System Operator market and submitted  
12 affidavits to FERC concerning the costs of new and existing generation resources on  
13 behalf of PJM, end of life transmission planning processes on behalf of LS Power, and  
14 transmission needs for transportation electrification on behalf of Michigan Electric  
15 Transmission Company. I have also co-written filed regulatory reports to the California  
16 Public Utilities Commission on the benefits of new high-voltage transmission facilities  
17 and to the Public Service Commission of the District of Columbia on electricity demand  
18 growth from transportation and heating electrification.

19  
20 **Q. Are you submitting any exhibits with your testimony?**

21 A. Yes, I am submitting the following exhibits:

- 22
- Ex.-WEPCO/WPSC-Hagerty-1: Resume of John Michael Hagerty;

- 1 • Ex.-WEPCO/WPSC-Hagerty-2: Entergy New Orleans Editorial Team, “New Orleans  
2 Power State: An Important Resource in the Ida Restoration Process,” September 2,  
3 2021;
- 4 • Ex.-WEPCO/WPSC-Hagerty-3: Energy Information Administration (“EIA”),  
5 “Capital Cost and Performance Characteristic Estimate for Utility Scale Electric  
6 Power Generating Technologies,” February 2020;
- 7 • Ex.-WEPCO/WPSC-Hagerty-4: Steven Martinez, “Three days later, more than  
8 18,000 We Energies customers still do not have power,” Milwaukee Journal Sentinel,  
9 August 13, 2021;
- 10 • Ex.-WEPCO/WPSC-Hagerty-5: Midcontinent Independent System Operator  
11 (“MISO”), “MISO January 30-31 Maximum Generation Event Overview,” February  
12 27, 2019;
- 13 • Ex.-WEPCO/WPSC-Hagerty-6: MISO, “Aligning Resource Availability and Need,”  
14 December 2019;
- 15 • Ex.-WEPCO/WPSC-Hagerty-7: MISO, “MISO Futures Report,” April 2021;
- 16 • Ex.-WEPCO/WPSC-Hagerty-8: Roger Lueken, et al., “New York’s Evolution to a  
17 Zero Emission Power System,” June 22, 2020;
- 18 • Ex.-WEPCO/WPSC-Hagerty-9: Jurgen Weiss and J. Michael Hagerty, “Achieving  
19 80% GHG Reduction in New England by 2050,” September 2019.
- 20 • Ex.-WEPCO/WPSC-Hagerty-10: U.S. Department of Energy (“DOE”), “Solar  
21 Futures Study,” September 2021;
- 22 • Ex.-WEPCO/WPSC-Hagerty-11: Wärtsilä Corporation, “Wärtsilä gas engines to burn  
23 100% hydrogen,” May 5, 2020;

- 1 • Ex.-WEPCO/WPSC-Hagerty-12: Wärtsilä Corporation, “New Orleans chooses  
2 Wärtsilä Smart Power solution for new power plant,” March 21, 2018;
- 3 • Ex.-WEPCO/WPSC-Hagerty-13: Wayne Barber, “Mid-Kansas plans 110 MW of new  
4 natural gas generation,” Transmission Hub, August 17, 2012;
- 5 • Ex.-WEPCO/WPSC-Hagerty-14: Xcel Energy, “Upper Midwest Integrated Resource  
6 Plan 2020–2034,” July 1, 2019;
- 7 • Ex.-WEPCO/WPSC-Hagerty-15: DTE Energy, “2019 Integrated Resource Plan  
8 Summary: Clean, Reliable Solutions to Power Michigan’s Future,” 2019;
- 9 • Ex.-WEPCO/WPSC-Hagerty-16: CenterPoint Energy, “CenterPoint Energy proposes  
10 next step in Smart Energy Future Plan,” June 17, 2021; and
- 11 • Ex.-WEPCO/WPSC-Hagerty-17: Central Iowa Power Cooperative (“CIPCO”),  
12 “CIPCO’s Summit Lake Expansion Project Reaches Commercial Operation,” April  
13 21, 2021.

14

15 **Q. Were these exhibits prepared or compiled by you or at your direction?**

16 A. Yes.

17

18 **Q. What is the purpose of your direct testimony?**

19 A. I understand that Wisconsin Electric Power Company (“WEPCO”) and Wisconsin Public  
20 Service Corporation (“WPSC”) (collectively, the “Joint Applicants”), which are both  
21 electric utility subsidiaries of WEC Energy Group Inc. (“WEC”), are proposing to  
22 construct a new reciprocating internal combustion engine (“RICE”) generating facility at  
23 the Weston Generating Station as part of WEC’s Generation Reshaping Plan (“GRP”).

1 The GRP includes retirement of several coal-fired units and their replacement primarily  
2 by new solar and storage resources by 2025, with the goal of significantly shifting the  
3 Joint Applicants' resource portfolios towards lower carbon emission generation  
4 resources, while maintaining an economic, safe and reliable electric generation fleet to  
5 serve their customers. The RICE units to be installed at Weston are a small part of the  
6 GRP and are intended to provide system support and energy timing benefits that are  
7 difficult to achieve with renewables and storage. My testimony provides an evaluation of  
8 the cost effectiveness and system benefits of the Weston RICE units as part of the Joint  
9 Applicants' proposed generation portfolio.

10  
11 **I. SUMMARY OF CONCLUSIONS**

12 **Q. Please summarize the conclusions you reach in your direct testimony.**

13 A. I conclude the following:

- 14 • The Weston RICE units are a cost-effective resource addition to serve Joint  
15 Applicants' load obligations due to their low all-in operating and capital recovery  
16 costs and unique performance capabilities for an increasingly decarbonized system.  
17 These performance capabilities include the ability to efficiently generate power when  
18 needed to meet peak demand and during periods with low or no renewable  
19 generation, to ramp quickly up and down in response to unexpected perturbation in  
20 the system, and to provide additional resilience benefits. The results of the Joint  
21 Applicants' computer simulations demonstrate that the unique characteristics of the  
22 proposed 7-unit RICE resource meet the system needs at least cost to customers even  
23 when alternative technologies were available to be selected by the model.

- 1           • The Weston RICE units can provide additional benefits in a highly decarbonized  
2 power system that were not captured by Joint Applicants’ simulations. In particular,  
3 those analyses did not capture the additional cost savings under possible scenarios  
4 with lower gas costs or during “droughts” in production from renewable energy  
5 resources (that are difficult to model but which will occur), or the need for sudden  
6 balancing in response to unplanned swings in hourly renewable energy generation.  
7 These are all situations where the Weston RICE units would have more value than  
8 has been quantified in the Joint Applicants’ simulations.
- 9           • Notwithstanding the Joint Applicants’ desire for a clean power system over the next  
10 few years, numerous studies of deep decarbonization find that dispatchable gas-fired  
11 resources will be needed to play a key role in reducing costs and assuring reliability  
12 in a future highly decarbonized power system. The Weston RICE units can reliably  
13 serve this role over the coming decades.
- 14          • Currently, many other utilities have found or are considering similar additions of  
15 RICE or other gas-fired resources as a part of their optimized supply portfolio as they  
16 shift towards low emitting resources to replace coal plants.

17

18 **II. SUMMARY OF THE JOINT APPLICANTS’ ANALYSIS**

19 **Q. Please describe the primary drivers for the Joint Applicants’ decision to add new**  
20 **generation resources to their system.**

21 A. Traditionally, generating resources are added to meet load growth. Here that is not the  
22 case. Instead, the Joint Applicants are planning to retire 1,385 MW of coal-fired power  
23 plants (Oak Creek 5 – 8 and Columbia 1-2) and 190 MW of natural gas-fired peaking

1 generation by 2025, which will decrease the amount of generation capacity and energy  
2 available to serve their existing native load and to meet their resource adequacy  
3 requirements. The new generation and storage resources are intended to replace the lost  
4 capacity and energy from the retiring coal-fired and gas-fired plants while reducing the  
5 greenhouse gas (“GHG”) emissions to meet the Joint Applicants’ goals of 60% and 80%  
6 reductions by 2025 and 2030, respectively (from 2005 levels), and full net carbon  
7 neutrality by 2050. These goals are consistent with the recommendations released in  
8 December 2020 by Governor Evers’ Climate Task Force.

9  
10 **Q. What resources did the Joint Applicants consider in their GRP planning analyses?**

11 A. The Joint Applicants considered multiple types of resources with diverse attributes as  
12 candidates for replacing the retired capacity and energy while reducing GHG emissions  
13 in a cost effective and reliable manner, including renewable energy resources (*i.e.*, solar  
14 and wind), battery energy storage systems (“BESS”), and several types of natural gas-  
15 fired resources, including combined cycle gas turbines (“CC”) and simple cycle gas  
16 turbines (“CT”), and RICE.

17 Solar and wind generation resources can provide the Joint Applicants with zero  
18 emission electricity generation that will reduce the CO<sub>2</sub> emissions of their generation  
19 portfolio. Both solar and wind generation are increasingly cost-effective as energy  
20 resources compared to new fossil-fired generation. But these resources are dependent on  
21 the intermittent availability of solar irradiation or wind for generating electricity that  
22 varies by hour, by day, by season and by year. For example, solar resources are relatively  
23 predictable based on the daily cycles of solar irradiation but naturally produce more

1 electricity in the summer than winter, and they are vulnerable to periods of lower output  
2 due to cloud cover. Wind resources are less predictable on an hourly and daily basis, are  
3 likewise intermittent, but tend to generate more electricity at night and in the winter  
4 (which can complement solar's generation patterns). Neither resource is dispatchable,  
5 though they can be curtailed during periods of excess generation to provide some  
6 reliability services. Because of their dependence on weather conditions rather than direct  
7 control by system operators, they provide less reliable capacity per MW of nameplate  
8 capacity than more conventional dispatchable resources.

9 BESS resources using lithium-ion technology can play a key role in balancing  
10 system demand and supply by charging during periods of excess renewable energy  
11 generation and/or low market energy prices and then discharging during periods of higher  
12 demand when renewable energy generation is low and/or energy prices are high. BESS  
13 resources are limited by its "duration," or the amount of time that the resource can inject  
14 power into the grid at 100% of its rated capacity on a full charge. In particular, the BESS  
15 resources considered by the Joint Applicants are limited to a four-hour duration due to the  
16 higher capital costs of longer duration BESS resources. BESS resources can play a  
17 crucial role by shifting the generation from renewable energy resources to periods of  
18 higher demand when cost effective to do so and when there is sufficient foresight into  
19 future system needs. The costs of BESS systems are declining rapidly such that they are  
20 becoming cost effective to deploy at scale, but their 4-hour duration means they are not a  
21 full substitute for dispatchable resources, such as gas-fired resources.

22 Natural gas-fired resources have been the mainstay of recent utility industry  
23 generation capacity expansion, which has been dominated for 20 years or so by CC and



1 CT units. There now are several different gas-fired technologies with varying balance of  
2 capital costs, operating costs, CO<sub>2</sub> emissions rates, and flexibility. Compared to CTs, the  
3 RICE technology can start up and ramp faster and at lower cost and operate more  
4 efficiently (*e.g.*, burn less fuel per MWh of generation) both at full load and partial load.  
5 RICE resources tend to have higher capital costs than CTs, but multiple-unit sites, such as  
6 the one planned at Weston, can achieve lower capital costs per megawatt of installed  
7 capacity. Compared to CCs, the RICE units are less efficient but are able to economically  
8 cycle off and on more often and to lower load levels without loss of efficiency to meet  
9 shorter demand periods when renewable energy resources are not available to produce.  
10 Due to their flexibility and efficiency, RICE units are cost effective resources to dispatch  
11 both on a day-ahead forecasted basis to provide low cost generation to serve demand and  
12 in real-time to mitigate the costs of unplanned changes in system conditions.

13 Similar to other gas resources, RICE units provide black-start capability that can  
14 support system restoration following a partial or complete collapse, as recently  
15 demonstrated by the RICE units in New Orleans following Hurricane Ida.<sup>1</sup>

16 Because of these added performance capabilities, RICE units typically have  
17 higher capital costs than alternative gas-fired technologies, as shown in recent EIA cost  
18 projections.<sup>2</sup> In this case, the Joint Applicants identified a lower capital cost plant by  
19 installing a 7-unit plant at the existing Weston site with the same design as the Kuester  
20 RICE plant recently installed in the Upper Peninsula of Michigan by another WEC  
21 electric utility subsidiary.

---


<sup>1</sup> Ex.-WEPCO/WPSC-Hagerty-2.

<sup>2</sup> RICE plants estimated to cost \$1,810/kW versus \$1,175/kW for a simple cycle aeroderivative CT.  
Ex.-WEPCO/WPSC-Hagerty-3, at 28.

1 **Q. What resources did the Joint Applicants select in their GRP?**

2 A. Joint Applicants selected a portfolio with a diverse blend of resources to replace several  
3 coal and natural gas plant retirements. As shown in Figure 1, the GRP portfolio includes  
4 construction of 946 MW of solar resources, 82 MW of wind resources, 558 MW of BESS  
5 resources, and 128 MW of RICE, and acquiring 200 MW of Alliant’s West Riverside  
6 combined-cycle facility.

7 *Figure 1: Generation Reshaping Plan Installed Capacity (MW)*



8 **Q. Please summarize how the Joint Applicants evaluated the GRP resources.**

9 A. The Joint Applicants evaluated the GRP resources by simulating the Joint Applicants’  
10 future electric generation fleet using Plexos, an industry-standard capacity expansion and  
11 production cost model. The Plexos model, which MISO uses in various system studies,  
12 identifies the least-cost set of resources to achieve system requirements over the next 30  
13 years, including the need to serve hourly system demand, meet reserve requirements to  
14 maintain reliability, and reduce emissions. The Joint Applicants developed a set of  
15 assumptions concerning the potential future portfolios of resources to meet these system  
16 requirements, including the type, amount, and characteristics of existing and new  
17

1 resources (including planned retirement dates) and other key assumptions, such as fuel  
2 (*i.e.*, natural gas and coal) prices, MISO energy and capacity market prices, and GHG  
3 emissions-related assumptions.

4 The Joint Applicants then ran simulations of their system in Plexos, which selects  
5 cost effective new resources to build (in this case, additional new resources beyond the  
6 GRP) and which resources to dispatch to meet future requirements to minimize costs to  
7 its customers over 30 years. The Joint Applicants simulated their generation fleet under a  
8 Base Case set of assumptions and 11 additional sensitivities. For each case, the Joint  
9 Applicants simulated the optimized dispatch and calculated resulting annual net costs,  
10 from which savings were derived relative to a case in which the Joint Applicants  
11 maintained their current resource mix. The Joint Applicants then estimated the present  
12 value of the cost savings for each scenario relative to the status quo.

13 The Joint Applicants determined that the GRP would save customers \$888 million  
14 over the 30 year period on a net present value basis for the combined WPSC/WEPCO  
15 system under the Base Case assumptions, and in the range of \$477 million to \$1,183  
16 million under sensitivity cases spanning alternative forecasts for natural gas prices, CO<sub>2</sub>  
17 prices, resource assumptions, and GRP resource costs.

18  
19 **Q. Have Joint Applicants performed additional analyses to confirm the cost**  
20 **effectiveness of Weston RICE units?**

21 A. Yes. In addition to the analysis described above, the Joint Applicants also ran additional  
22 simulations in Plexos in response to a data request from the PSC (PSC-Grant-1). In those  
23 simulations, the Plexos model selected new resources from the available resources


1 currently in the MISO generation queue, generic new resources, and alternative  
2 technologies to replace retiring gas capacity at the Weston and Marinette sites, including  
3 RICE (single unit, 3-unit or 7-unit) plants, combustion turbine plants, or BESS resources.  
4 Across each of the three scenarios considered, Plexos identified the proposed 7-unit  
5 RICE technology as a part of the least-cost portfolio. These results demonstrate that the  
6 unique characteristics of the proposed 7-unit RICE resource meet the Joint Applicants'  
7 system needs at least cost to customers even when alternative technologies were available  
8 to be selected by the model.

9  
10 **Q. Please explain how the RICE units operate in the Joint Applicants' simulations to**  
11 **provide such benefits.**

12 A. The Joint Applicants' simulations show that the Weston RICE units perform primarily  
13 when there is limited or no output from renewable energy resources. For example, Figure  
14 2a below shows the average hourly generation in Winter 2025 (January through March)  
15 from the WEC simulations for three resources: total renewable generation (wind and  
16 solar) in blue; Weston RICE generation in orange, and battery storage charging and  
17 discharging in green. The Weston RICE units operate in the hours before renewable  
18 generation increases in the morning from Hour 6 to Hour 7, but then decrease during  
19 peak solar generation hours in the middle of the day. The RICE units then operate at  
20 higher level of output again after renewable generation decreases in the evening from  
21 Hour 17 to Hour 21 to meet the evening peak demand. Whereas BESS is primarily  
22 available to serve the evening peak demand after charging during the day (as seen in the  
23 negative generation from hours 12 to 16), the Weston RICE units are dispatched to meet

1 both the morning and evening peak hours. They are also dispatched during the afternoon  
 2 in Summer 2025, as shown in Figure 2b to serve the higher mid-day summer demand.  
 3 Throughout the year, the RICE units operate at a 21% capacity factor with over half of  
 4 their generation occurring during hours with relatively low renewable energy generation  
 5 (less than 40% of maximum output).


6 *Figure 2: 2025 Hourly Average Generation by Resource Type*  
 7 (a) Winter 2025 (b) Summer 2025



8 By 2035, the Weston RICE units are projected in the modeling scenarios to  
 9 operate less frequently and only during hours with low renewable generation due to the  
 10 expected significant addition of solar generation, as shown in Figure 3 below. As a fast-  
 11 start resource with low startup costs, the RICE units are able to efficiently fill the short  
 12 windows of generation needed to serve load, which makes the RICE technology well-  
 13 suited to meet the Joint Applicants' needs while also being cost-effective for customers.  
 14 As shown in Figure 3a, generation during the winter in 2035 is limited to the two-hour  
 15 period from Hour 6 to Hour 7 just before renewable generation increases and then during  
 16 evening peak hours from Hour 17 to Hour 23. Generation during the summer months is  
 17 limited to just the evening hours from Hour 17 to midnight to supplement output from  
 18

1 BESS resources to meet load. The 2035 annual capacity factor decreases to 14% as a  
2 greater share of the generation will come from renewable energy resources.

3 *Figure 3: 2035 Hourly Average Generation by Resource Type*  
4 (a) Winter 2035 (b) Summer 2035



5  
6 This pattern of use demonstrates the benefits that the RICE units will provide in  
7 the Joint Applicants' systems as levels of renewable energy increase, by efficiently  
8 generating during both short and long gaps that occur between renewable energy  
9 generation and customer demand. Importantly, these benefits will arise if the future  
10 system conditions align with those assumed by the Joint Applicants. If the system  
11 conditions are more volatile than that, the RICE units will be even more important, as  
12 they are particularly capable of responding to such unplanned changes.

13  
14 **Q. In your introductory summary, you suggested the analysis performed by the Joint**  
15 **Applicants may not fully capture the benefits of the Weston RICE units. Please**  
16 **explain what other attributes of the units may be beneficial for customers.**

17 **A.** The Joint Applicants' analysis captures the value of the proposed Weston RICE units  
18 under the planned (or projected) system conditions for load, weather, and fuel costs  
19 included in the simulations. However, the simulations may underestimate the value of the  
20 Weston RICE units in two ways: (1) by not including a scenario with lower natural gas

1 prices than the current U.S. Energy Information Administration’s Annual Energy Outlook  
2 (“AEO”) forecasts, *e.g.* closer to the prices reflected in current natural gas futures prices,  
3 which would reduce the costs of operating the RICE plant, and (2) by modeling  
4 normalized system conditions that do not reflect several real-world system stress  
5 conditions, such as short- to mid-length periods (hours or a few days) of much higher  
6 electricity demand, unplanned generation and transmission outages, and unexpected  
7 variations (possibly including large gaps or “droughts”) in renewable generation. The  
8 benefits of the Weston RICE units are likely to be high during these periods due to the  
9 flexibility they provide to the Joint Applicants’ system.

10  
11 **Q. Please explain the additional benefits of the Weston RICE units in a future that**  
12 **could have lower natural gas prices than were evaluated by the Joint Applicants.**

13 A. The projected natural gas price has a significant impact on the operation of the Weston  
14 RICE units as fuel costs are the primary operating costs for these resources and factor  
15 into the frequency at which they operate and the costs of doing so. Higher natural gas  
16 prices will increase the fuel costs of the Weston RICE units. In a system with a mix of  
17 coal and gas resources, all else equal, higher fuel costs will result in the RICE units  
18 operating less frequently and lower fuel costs will result in them operating more  
19 frequently.

20 The Joint Applicants’ simulations of the GRP included three gas price scenarios:  
21 (1) an AEO Reference Case based on the projected prices from the AEO 2020 Reference  
22 Case, (2) a High Natural Gas case by calculating and adding one standard deviation to the  
23 AEO Reference Case forecast, and (3) an AEO \$15 CO<sub>2</sub> Fee case, in which natural gas


1 prices are slightly higher than the Reference Case through 2028 and then equivalent  
2 through 2035. The simulations did not include a low natural gas price case that would  
3 tend to increase the benefits of the RICE Plants.

4 I compared the natural gas prices in the Joint Applicants' simulations from the  
5 AEO 2020 Reference Case to the natural gas futures prices at two gas hubs as of  
6 September 2, 2021: Chicago and Henry Hub, as shown in Figure 4 below. The futures  
7 prices at the two gas hubs are very similar until 2028, the last year that Chicago prices are  
8 available. As shown, the natural gas price the Joint Applicants assumed in their  
9 simulations are about \$1/MMBtu higher than the current futures prices on average from  
10 2025 to 2033. If sustained, the lower natural gas prices reflected in the futures products  
11 would decrease the production costs of the Weston RICE units by about \$8/MWh, based  
12 on the assumed RICE heat rate of 8,295 Btu/kWh, and would therefore increase how  
13 frequently they are dispatched and the benefits accruing to customers from their inclusion  
14 in the GRP.



1  
2

Figure 4: Comparison of Joint Applicants' Assumed Natural Gas Price versus Current Gas Futures Prices



3  
4

5 **Q. Is it your opinion that the futures prices of natural gas are a better forecast than the**  
6 **AEO or similar fundamental predictions?**

7 A. Not necessarily. Futures products tend to be thinly traded after only a few years forward  
8 and they are a riskless (guaranteed) price for the traders. Thus, futures products tend to  
9 underestimate realized spot prices. However, for the past several years futures prices for  
10 natural gas have often been closer to the realized spot gas prices than fundamental  
11 forecasts, such as those contained in the AEO, so it is prudent to consider which portfolio  
12 of resources would be most attractive and the benefits of the RICE units within that  
13 portfolio if such lower gas prices than the AEO's reference case were to occur.

1 **III. ADDITIONAL BENEFITS WITH INCREASING RENEWABLE GENERATION**

2 **Q. Please elaborate on the real-world system stress conditions you mentioned above**  
3 **that are not captured in the Joint Applicants’ simulations and would increase the**  
4 **benefits of the Weston RICE units.**

5 A. The simulation analysis performed by the Joint Applicants to evaluate the GRP assumed  
6 normalized system conditions including projected system 50/50 peak demand, limited  
7 unplanned outages of generation and transmission resources, and normalized renewable  
8 generation profiles. However, the real-world power system must be able to respond to  
9 unplanned system conditions that frequently stress the system and increase costs to  
10 customers. The frequency of these stress conditions have been increasing recently.

11 For example, system demand frequently exceeds the planned peak demand  
12 included in the simulations, but the cold weather that hit much of the United States in  
13 February 2021 further stressed the system due to the geographic scope of the cold  
14 temperatures and the extended length of the cold weather event. In mid-August 2021,  
15 storms that swept across Wisconsin resulted in the largest outages of system  
16 infrastructure in We Energies’ history.<sup>3</sup>

17 The increase in renewable energy resources is adding more frequent unplanned  
18 stress conditions, as solar and wind generation can decrease dramatically within an hour  
19 due to heavy cloud cover or shifting wind conditions such that other resources must be  
20 available to respond. For example, MISO called a maximum generation emergency, or  
21 “Max Gen” event, at 5 A.M. on January 30, 2019 due to an unexpected 6,000 MW

---

<sup>3</sup> Ex.-WEPCO/WPSC-Hagerty-4.

1 decrease in wind generation.<sup>4</sup> The addition of the Weston RICE units would mitigate the  
2 costs of these events to the Joint Applicants' customers.

3 MISO has identified the reliability impacts of the shifting resource mix and  
4 system conditions in a December 2019 whitepaper:

5 A total of 12 emergencies occurred beginning in the 2016-17 planning year  
6 through half of the subsequent planning year. That trend has continued as MISO  
7 entered MISO Market Capacity Emergency procedures 27 times through the  
8 summer of 2019. These events have occurred multiple times in every season  
9 reinforcing the notion that 'every hour matters.' This differs greatly from the  
10 assumption that the system will be reliable for all 8,760 hours of the year as long  
11 as utilities have enough generation capacity to meet demand on the 'peak hour' of  
12 the year, which typically occurs on an exceptionally hot and humid summer day.<sup>5</sup>

13  
14 **Q. Please summarize the types of performance uncertainties and challenges that  
15 renewable generation adds to the operation of the Joint Applicants' power system.**

16 **A.** The increasing amount of renewable generation resources added to the Joint Applicants'  
17 power system, and to the MISO region as a whole, creates additional mid-term (daily to  
18 weekly) uncertainty and short-term (hourly) uncertainty in serving future demand. In the  
19 mid-term, additional reliance on renewable energy can result in extended periods of low  
20 generation due to occasional renewable energy droughts that require other generation  
21 resources like the dispatchable generation from the Weston RICE units to make up the  
22 shortfall. At the hourly level, renewable energy increases the uncertainty between the

---

<sup>4</sup> Ex.-WEPCO/WPSC-Hagerty-5.

<sup>5</sup> Ex.-WEPCO/WPSC-Hagerty-6, at 6.

1 forecasted day-ahead generation and actual real-time generation, resulting in periods of  
2 unplanned shortfalls in generation.


3 The impacts of the extended renewable energy droughts and real-time shortfalls  
4 on Joint Applicants' customers are made more significant by the correlation of output  
5 from renewable energy resources owned by the Joint Applicants and the renewable  
6 energy resources in the MISO North market. For example, correlation of renewable  
7 output with the rest of the MISO region creates significant costs risks for Joint Applicants  
8 during periods of low output from their renewable resources, since the rest of MISO  
9 would also be likely short in renewables and the cost of market purchases are likely to be  
10 high. This challenge will only increase as more utilities across region shift their resource  
11 mix towards renewable energy resources.

12  
13 **Q. Have you analyzed the potential for a multi-day drought in renewable energy  
14 generation that the Joint Applicants are likely to experience in their future system?**

15 A. Yes. Due to the higher levels of wind generation that have currently been added in  
16 Wisconsin and MISO North, I analyzed historical hourly wind generation in the MISO  
17 region since 2019 and identified several multi-day periods during which the average wind  
18 generation was significantly below the average generation for that month. For example,  
19 Figure 5 below shows that in January 2019 there was a seven-day period in which total  
20 wind generation averaged 77,325 MWh per day, which is 56% below the monthly  
21 average of 175,205 MWh per day. A winter period like this one would be especially  
22 challenging for a future power system with significantly greater renewable generation  
23 due to the relatively low output of solar resources in January.

1

Figure 5: January 2019 MISO Daily Wind Generation



2

3

The wind generation facilities owned by the Joint Applicants experienced a

4

similar drought in wind generation on their system during this period in January 2019.

5

Figure 6 below shows that during the same seven-day period in which MISO-wide wind

6

generation was more than 50% below average (dark blue bars) the same was true for the


7

wind generation owned by the Joint Applicants (green bars).

8

Figure 6: MISO and Joint Applicant Daily Wind Generation in January 2019 (as % of Total January Generation)

9




10

1 **Q. Have you analyzed how well correlated the wind generation owned by the Joint**  
2 **Applicants is to the total wind generation across MISO?**

3 A. Yes. The wind generation across all of MISO and that of the Joint Applicants' resources  
4 are highly correlated. Figure 7 below shows daily wind generation in January 2019 to  
5 July 2021 by the Joint Applicants' wind resources (on the x-axis) versus the total wind  
6 generation across MISO (on the y-axis) as well as a linear trend line (orange line)  
7 demonstrating the correlation between the two. Due to the high correlation between  
8 WEC's wind generation and total wind generation in MISO, it is likely that the days  
9 when the wind generation owned by the Joint Applicants is low will tend to overlap with  
10 the days when total wind generation in MISO will also be low.

11 *Figure 7: Daily Generation by Joint Applicants' Wind Resources versus*  
12 *Total MISO Wind Resources, 2019 to 2021*



13

1 **Q. What are the benefits of the Weston RICE units during renewable energy droughts?**

2 A. There are two significant benefits of the Weston RICE units to consider. First, in hours  
3 with low wind generation in MISO, energy prices would tend to be higher, hence Joint  
4 Applicant's cost of purchasing power from the market to address its net short position  
5 would also be higher. Adding a dispatchable and efficient resource like the Weston RICE  
6 units will mitigate the increase in cost of market purchases during these periods by  
7 limiting, if not eliminating, the need for high-cost market purchases during these periods.

8 Second, the multi-day duration of depressed wind generation periods requires a  
9 longer-term duration resource than a battery storage resource currently can provide. If a  
10 similar period as observed in January 2019 were included in the Joint Applicant's  
11 simulations for 2030, the lower wind generation would result in a 10,645 MWh shortfall  
12 over a week in January, or about 63 MW on average over 168 hours.<sup>6</sup> The Weston RICE  
13 units could be dispatched to meet such a shortfall. By contrast, it would require 2,661  
14 MW of 4-hour battery storage resources to be fully charged at the beginning of this  
15 period to provide a similar level of energy to meet such a shortfall.

16

17 **Q. Have you estimated the amount of hourly forecast error for the Joint Applicants'**  
18 **wind resources?**

19 A. Yes. I analyzed the historical wind generation from the resources owned by the Joint  
20 Applicants since 2017 and compared the day-ahead forecasted hourly wind generation to  
21 the real-time actual generation to estimate the forecast error for their wind generation  
22 resources.

---


<sup>6</sup> The Joint Applicants' simulations assume 2,716 MWh of daily average wind generation in January 2030. A 56% reduction in the daily generation over 7 days is 10,645 MWh.

1                   Figure 8 below shows the forecast error since 2017 of the Joint Applicants' wind  
2 resources, in terms of the difference between the real-time actual generation and the day-  
3 ahead forecasted generation. A positive difference indicates that real-time actual  
4 generation exceeded the day-ahead forecasted generation in a given hour, while a  
5 negative difference indicates real-time actual generation fell short of the day-ahead  
6 forecasted generation. On average, day-ahead forecasted generation and real-time actual  
7 generation were similar as shown by the greatest share of hours falling between -25 MW  
8 and +25 MW in the figure. But in about 15% of hours since 2017, the real-time wind  
9 generation was more than 50 MW lower than forecasted day-ahead and in 5% of hours  
10 the real-time generation was more than 100 MW lower. When real-time generation is  
11 significantly below the forecasted generation system operators must rely on fast-  
12 responding and dispatchable resources like the Weston RICE units to make up the  
13 difference.



1  
2

Figure 8: Joint Applicants' Wind Resource Forecast Error, 2017-2021  
(Hourly Real-Time Generation minus Hourly Day-Ahead Generation)



3

For example, on September 6, 2020 the Joint Applicants forecasted day-ahead

4

wind generation significantly higher than actual real-time generation, as shown in Figure

5

9 below. I understand that some of the difference in generation from 7 A.M. to 10 A.M.

6

was due to curtailments of the real-time wind generation. During the period from 11

7

A.M. to midnight, forecasted day-ahead was 6,590 MWh but actual wind generation was

8

only 3,720 MWh during this timeframe, a total shortfall of 2,870 MWh over this period


9

or 205 MW on average.

10

1  
2

Figure 9: Joint Applicants' Wind Resource Real-Time and Day-Ahead Generation, September 6 – 7, 2020



3  
4

5 **Q. What are the benefits of the Weston RICE units during periods of intra-day hourly**  
6 **forecast error, such as those just shown?**

7 A. Similar to extended renewable energy droughts, the addition of the Weston RICE units  
8 will mitigate the cost impacts of relying on potentially high-cost spot market purchases to  
9 serve demand during these hours in which wind generation suddenly is much lower than  
10 expected. The units could quickly start up to make up the shortfall in wind generation  
11 instead of relying on imports.

12 The Weston RICE units will be especially valuable during extended periods of  
13 forecast error similar to the one experienced in September 2020. While the units could be  
14 dispatched as necessary to make up a portion of the shortfall, BESS resources would not  
15 be a cost effective approach to do so as (1) they are unlikely to be fully charged at the

1 beginning of this unplanned shortfall because batteries tend to charge during the middle  
2 of the day during peak solar production, and (2) even if they were fully charged, 717 MW  
3 of 4-hour duration BESS resources would be necessary to provide the same level of  
4 output to make up for the shortfall during this period.

5  
6 **Q. Did the Joint Applicants consider these variations in hourly wind output in their**  
7 **simulations?**

8 A. No. The Joint Applicants did not consider real-time uncertainty of wind and solar  
9 generation in their simulations. Real-time uncertainty is not commonly considered in  
10 capacity expansion models like Plexos but can be included in more detailed production  
11 cost simulations.

12  
13 **Q. Have studies of deeply decarbonized power systems that rely primarily on**  
14 **renewable energy generation identified benefits of dispatchable gas-fired generation**  
15 **resources?**

16 A. Yes, they have. Nearly all recent decarbonization studies that have simulated future  
17 power system demonstrate the significant challenge in reaching a deeply or fully  
18 decarbonized system, especially if the only available technologies are renewable  
19 generation and storage. The challenge of operating a system primarily with renewable  
20 energy resources is the high correlation across multiple renewable generation resources  
21 within a given region, as demonstrated for wind generation resources in Figure 7 above.  
22 To mitigate this challenge, a considerable amount of additional renewable energy  
23 resources have to be built in locations with less correlated generation along with  
24 corresponding amounts of long-distance high-voltage transmission and long-duration

1 storage to achieve the last few percent of decarbonization. On top of that, there is a risk  
2 of renewable droughts (as discussed above) which may transcend the limits of even large  
3 amounts of storage. Accordingly, given current technologies, some portion of any future  
4 decarbonized system will need to be dispatchable since units like RICE will not have this  
5 problem of its output being highly correlated with renewable energy resources.

6 For instance, the MISO Futures Report released in April 2021 included a future  
7 scenario (Future 3) in which MISO-wide GHG emissions decrease by 81%.<sup>7</sup> The capacity  
8 of gas-fired resources in Future 3 increases from 71 GW in 2020 to 109 GW in 2039 and  
9 produces 31% of the total energy generation in the market.<sup>8</sup>

10 A report by my colleagues at Brattle for the New York Independent System  
11 Operator on the future generation mix to achieve New York State’s goal of achieving  
12 100% zero-emissions resources by 2040 found that the total gas-fired generation capacity  
13 would have to increase from 23 GW in 2020 to 34 GW in 2040.<sup>9</sup> At the same time, the  
14 total generation from the dispatchable gas-fired resources would fall from 59 terawatt  
15 hours (“TWh”) in 2020 using conventional natural gas to 20 TWh in 2040 burning  
16 renewable natural gas (“RNG”).

17 Similarly, I conducted a study on the generation mix necessary to achieve 80%  
18 reductions in economy-wide GHG emissions by 2050 in New England and concluded  
19 that 31 GW to 45 GW of dispatchable natural gas-fired capacity would be necessary in

---

<sup>7</sup> Ex.-WEPCO/WPSC-Hagerty-7, at 6.

<sup>8</sup> The growth in natural gas capacity in Future 3 is partially due to the nearly 50% increase in total annual energy demand primarily driven by transportation and heating electrification. *Id.* at 36.

<sup>9</sup> Ex.-WEPCO/WPSC-Hagerty-8, at 22-23, 61-64.

1 2050 to meet these goals, with the higher end of the range occurring in a scenario with  
2 significant RNG development.<sup>10</sup>

3 At the national level, the recently released Solar Futures Study by the U.S.  
4 Department of Energy (“DOE”) found that dispatchable resources, primarily CTs  
5 operating on renewable or zero-carbon fuel such as hydrogen and RNG, are a “critical  
6 contributor” to maintaining resource adequacy and operational reliability in a fully  
7 decarbonized power system.<sup>11</sup> Similar to the points discussed above for the Joint  
8 Applicants’ system, the DOE study finds that the operation of the dispatchable resources  
9 tends to be relatively limited (4-5% capacity factor) and highly dependent on weather  
10 conditions and the resulting availability of renewable energy generation, with the  
11 dispatchable resources filling the gaps in renewable energy generation. The study in  
12 particular highlights a simulation of a five-day renewable energy drought in 2050 (based  
13 on historical weather conditions in ERCOT in January 2007) when nearly 50 GW of  
14 dispatchable resources are necessary serve demand, noting that the same five-day period  
15 in other years requires very limited operation of the dispatchable resources.

16  
17 **Q. Are the Weston RICE units cost-effective resources in serving a similar need for the**  
18 **Joint Applicants in achieving their long-term GHG reduction goals?**

19 A. Yes, the Weston RICE units provide an efficient and fast-ramping resource that will  
20 adapt to the needs of the system as renewable energy generation increases and greater  
21 reductions in GHG emissions occur. As shown above, the capacity factor of the Weston  
22 RICE units decrease from 21% in 2025 to 14% in 2035 as their role shifts from

---

<sup>10</sup> Ex.-WEPCO/WPSC-Hagerty-9, at 16, 19.

<sup>11</sup> Ex.-WEPCO/WPSC-Hagerty-10, at 58-60.

1 generating to meet mid-day summer demand in the near-term to exclusively operating  
2 when renewable energy generation is low in 2035.

3 In addition, Wärtsilä, the manufacturer of the Weston RICE units, is currently  
4 developing the capability for the units to operate on RNG or hydrogen.<sup>12</sup> Wärtsilä has  
5 already tested its units with a blend of 60% hydrogen and 40% natural gas and separately  
6 with 100% RNG.

#### 7 8 **IV. EXPERIENCE WITH RICE AND RENEWABLES FROM OTHER UTILITIES**

9 **Q. Are other utilities choosing to install RICE units or other peaking gas resources as**  
10 **part of their plans to replace retiring fossil generation resources?**

11 A. Yes, other utilities replacing older coal- and gas-fired capacity are building dispatchable  
12 and flexible, efficient gas-fired resources, including RICE units.

13 As noted above, Entergy Louisiana added 128 MW of Wärtsilä RICE units in  
14 New Orleans to replace a retiring dual fuel steam turbine plant, and as noted above these  
15 RICE units helped the city recover from Hurricane Ida.<sup>13</sup> In addition, the Central Iowa  
16 Power Cooperative installed 110 MW of RICE units in April 2021 to provide  
17 “dispatchable, quick-start natural gas capacity to run when the wind and sun aren’t  
18 producing electricity.”<sup>14</sup> Mid-Kansas Electric in wind-heavy western Kansas installed a  
19 12-unit 100 MW RICE facility at its Rubart substation in 2014, noting its fast start  
20 capability, quick response to market conditions, and ability to support the integration of  
21 wind energy.<sup>15</sup>

---

<sup>12</sup> Ex.-WEPCO/WPSC-Hagerty-11.

<sup>13</sup> Ex.-WEPCO/WPSC-Hagerty-12.

<sup>14</sup> Ex.-WEPCO/WPSC-Hagerty-17.

<sup>15</sup> Ex.-WEPCO/WPSC-Hagerty-13.

1           Several of the larger utilities in MISO North that are retiring major coal plants are  
2 choosing to include new gas plants as a part of their portfolios of replacement resources.  
3 Xcel Energy in Minnesota selected a new 800 MW gas CC as a part of its plan to replace  
4 3,000 MW of retiring coal plants and is extending the life of 150 MW of gas CTs, in  
5 addition to installing over 5,000 MW of renewable resources.<sup>16</sup> DTE in Michigan is also  
6 replacing three retiring coal plants with a gas CC and a mix of renewable energy  
7 resources, energy efficiency, and demand response.<sup>17</sup> CenterPoint Energy in Indiana  
8 recently submitted applications to build 460 MW of new gas CTs to replace the 490 MW  
9 A.B. Brown coal-fired plant in addition to nearly 500 MW of solar capacity.<sup>18</sup>

10           By identifying these examples, I am not suggesting that the Joint Applicants  
11 should blindly imitate those systems, as each has its own idiosyncratic needs and  
12 opportunities for cost effective resources. However, the recurring pattern of many utilities  
13 finding the units like these RICE ones improve performance in their planned systems is  
14 indicative that there are some important benefits to be had.

15  
16 **Q. Does this conclude your direct testimony?**

17 **A. Yes.**

---

<sup>16</sup> Ex.-WEPCO/WPSC-Hagerty-14.

<sup>17</sup> Ex.-WEPCO/WPSC-Hagerty-15.

<sup>18</sup> Ex.-WEPCO/WPSC-Hagerty-4.