

CITY OF EVANSVILLE WATER & LIGHT

Power Cost Adjustment Clause

All metered rates shall be subject to a positive or negative power cost adjustment charge equivalent to the amount by which the current cost of power (per kilowatt-hour of sales) is greater or lesser than the base cost of power purchased (per kilowatt-hour of sales).

The current cost per kilowatt-hour of energy billed is equal to the cost of power purchased for the most recent month, divided by the kilowatt-hours of energy sold. The monthly adjustment (rounded to the nearest one one-hundredth of a cent) is equal to the current cost less the base cost. The base cost of power (U) is \$0.0929 per kilowatt-hour.

Periodic changes shall be made to maintain the proper relative structure of the rates and to insure that power costs are being equitably recovered from the various rate classes. If the monthly adjustment (A) exceeds \$0.0150 per kilowatt-hour, for more than three times in a 12-month period (current plus preceding 11-months), the company shall notify the Public Service Commission of Wisconsin separate from its monthly PCAC report of the need to evaluate a change in rates to incorporate a portion of the power cost adjustment into the base rates.

For purposes of calculating the power cost adjustment charge, the following formula shall be used:

$$A = \frac{C}{S} - U$$

- A is the power cost adjustment rate in dollars per kilowatt-hour rounded to four decimal places applied on a per kilowatt-hour basis to all metered sales of electricity.
- S is the total kilowatt-hours sold during the most recent month.
- U is the base cost of power, which equals the average cost of power purchased per kilowatt-hour of sales for the test year period. This figure remains constant in each subsequent monthly calculation at \$0.0929 per kilowatt-hour until otherwise changed by the Public Service Commission of Wisconsin.
- C is the cost of power purchased in dollars in the most recent month. Cost of power purchased for calculation of C are the monthly amounts which would be recorded in the following accounts of the Uniform System of Accounts:

Class A & B utilities	Accounts 555
Class C utilities	Accounts 545

Public Service Commission of Wisconsin

CITY OF EVANSVILLE WATER & LIGHT

Residential Service – Optional Time of Day

Application: This rate schedule is optional to all Rg-1, Residential Service customers. Customers that wish to be served on this rate schedule must apply to the utility for service. Once an optional customer begins service on this rate schedule, the customer shall remain on the rate for a minimum of one year. Any customer choosing to be served on this rate schedule waives all rights to billing adjustments arising from a claim that the bill for service would be less on another rate schedule than under this rate schedule.

Once on this rate, the utility will review billing annually according to Wis. Admin. Code ch. PSC 113.

Customer Charge: Single-phase: \$11.00 per month.
 Three-phase: \$16.00 per month.

Energy Charge: On-peak: \$0.2250 per kilowatt-hour (kWh).
 Off-peak: \$0.0790 per kWh.

Power Cost Adjustment Clause: Charge per all kWh varies monthly. See schedule PCAC.

Pricing Periods: On-peak: The three on-peak periods available are:
 7:00 a.m. to 7:00 p.m. (closed to new customers)
 8:00 a.m. to 8:00 p.m.
 9:00 a.m. to 9:00 p.m. (closed to new customers)
Monday through Friday, excluding holidays, specified below.

Off-peak: All times not specified as on-peak including all day Saturday and Sunday, and the following holidays: New Year’s Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day, and Christmas Day, or the day designated to be celebrated as such.

Prompt Payment of Bills: Same as Rg-1.

Minimum Monthly Bill: The minimum monthly bill shall be the customer charge.

Moving Provision: If a customer moves within the utility’s service territory, both the original and the new customer have the option to retain time-of-day billing or to transfer to the Residential Service rate, Rg-1, at no cost to the customer.

Public Service Commission of Wisconsin

CITY OF EVANSVILLE WATER & LIGHT

General Service

Application: This rate will be applied to single and three-phase customers. This includes commercial, institutional, government, farm, and other customers. The monthly Maximum Measured Demand of customers served on this rate shall not exceed 45 kilowatts for three or more months in a consecutive 12-month period.

Gs-1 customers shall be transferred into the appropriate demand class as soon as the application conditions of that class have been met.

Customer Charge: Single-phase: \$12.00 per month.
 Three-phase: \$17.00 per month.

Energy Charge: \$0.1337 per kilowatt-hour (kWh).

Power Cost Adjustment Clause: Charge per all kWh varies monthly. See schedule PCAC.

Minimum Monthly Bill: The minimum monthly bill shall be the customer charge.

Prompt Payment of Bills: Same as Rg-1.

Farm Customer: Defined as a person or organization using electric service for the operation of an individual farm, or for residential use in living quarters on the farm occupied by persons principally engaged in the operation of the farm and by their families. A farm is a tract of land used to raise or produce agricultural and dairy products, for raising livestock, poultry, game, fur-bearing animals, or for floriculture, or similar purposes, and embracing not less than 3 acres; or, if small, where the principal income of the operator is derived therefrom. (Otherwise, the service used for residential purposes is classed as residential, and that used for commercial is classed as general service.)

Determination of Maximum Measured Demand: The Maximum Measured Demand in any month shall be that demand in kilowatts necessary to supply the average kilowatt-hours in 15 consecutive minutes of greatest consumption of electricity during each month. Such Maximum Measured Demand shall be determined from readings of permanently installed meters or, at the option of the utility, by any standard methods or meters. Said demand meter shall be reset to zero when the meter is read each month.

Public Service Commission of Wisconsin

CITY OF EVANSVILLE WATER & LIGHT

General Service – Optional Time-of-Day

Application: This rate schedule is optional to all Gs-1, General Service customers. Customers that wish to be served on this rate schedule must apply to the utility for service. Once an optional customer begins service on this rate schedule, the customer shall remain on the rate for a minimum of one year. Any customer choosing to be served on this rate schedule waives all rights to billing adjustments arising from a claim that the bill for service would be less on another rate schedule than under this rate schedule.

Once on this rate, the utility will review billing annually according to Wis. Admin. Code ch. PSC 113.

Gs-2 customers shall be transferred to the appropriate demand class as soon as the application conditions of that class have been met.

Customer Charge: Single-phase: \$12.00 per month.
 Three-phase: \$17.00 per month.

Energy Charge: On-peak: \$0.2260 per kilowatt-hour (kWh).
 Off-peak: \$0.0796 per kWh.

Power Cost Adjustment Clause: Charge per all kWh varies monthly. See schedule PCAC.

Pricing Periods: On-peak: 8:00 a.m. to 8:00 p.m.
 Monday through Friday, excluding holidays, specified below.

Off-peak: All times not specified as on-peak including all day Saturday and Sunday, and the following holidays: New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day, and Christmas Day, or the day designated to be celebrated as such.

Prompt Payment of Bills: Same as Rg-1.

Minimum Monthly Bill: The minimum monthly bill shall be the customer charge.

Moving Provision: If a customer moves within the utility’s service territory, both the original and the new customer have the option to retain time-of-day billing or to transfer to the General Service rate, Gs-1, at no cost to the customer.

Public Service Commission of Wisconsin

CITY OF EVANSVILLE WATER & LIGHT

Small Power Service

Application: This rate will be applied to customers for all types of service if their monthly Maximum Measured Demand is in excess of 45 kilowatts (kW) per month for three or more months in a consecutive 12-month period, but not greater than 200 kW per month for three or more months in a consecutive 12-month period.

Customers billed on this rate shall continue to be billed on this rate until their monthly Maximum Measured Demand is less than 45 kW per month for 12 consecutive months.

Customer Charge: \$50.00 per month.

Distribution Demand Charge: \$1.50 per kW of distribution demand.

Demand Charge: \$8.00 per kW of billed demand.

Energy Charge: \$0.0927 per kilowatt-hour (kWh).

Power Cost Adjustment Clause: Charge per all kWh varies monthly. See schedule PCAC.

Prompt Payment of Bills: Same as Rg-1.

Minimum Monthly Bill: The minimum monthly bill shall be equal to the customer charge, plus the distribution demand charge.

Determination of Maximum Measured Demand: The Maximum Measured Demand in any month shall be that demand in kilowatts necessary to supply the average kilowatt-hours in 15 consecutive minutes of greatest consumption of electricity during each month. Such Maximum Measured Demand shall be determined from readings of permanently installed meters or, at the option of the utility, by any standard methods or meters. Said demand meter shall be reset to zero when the meter is read each month.

Determination of Billed Demand: The Billed Demand shall be the Maximum Measured Demand.

Determination of Distribution Demand: The Distribution Demand shall be the highest monthly Maximum Measured Demand occurring in the current month or preceding 11-month period.

(Continued on next page)

CITY OF EVANSVILLE WATER & LIGHT

Small Power Service

Discounts: The monthly bill for service will be subject to the following discounts applied in the sequence listed below.

Primary Metering Discount: Customers metered on the primary side of the transformer shall be given a 1.25 percent discount on the monthly energy charge, distribution demand charge, and demand charge. The PCAC and the monthly customer charge will not be eligible for the primary metering discount.

Transformer Ownership Discount: Customers who own and maintain their own transformers or substations shall be given a credit of \$0.15 per kW of distribution demand. Customer-owned substation equipment shall be operated and maintained by the customer. Support and substation equipment is subject to utility inspection and approval.

Public Service Commission of Wisconsin

CITY OF EVANSVILLE WATER & LIGHT

Small Power Service – Optional Time of Day Service

Application: This rate schedule is optional to all Cp-1 customers. Customers that wish to be served on this rate schedule must apply to the utility for service. Once an optional customer begins service on this rate schedule, the customer shall remain on the rate for a minimum of one year. Any customer choosing to be served on this rate schedule waives all rights to billing adjustments arising from a claim that the bill for service would be less on another rate schedule than under this rate schedule.

Once a customer is on this rate, the utility will review their billing annually according to Wis. Admin. Code ch. PSC 113.

Customer Charge: \$50.00 per month.

Distribution Demand Charge: \$1.50 per kW of distribution demand.

Demand Charge: \$8.00 per kW of on-peak billed demand.

Energy Charge: On-peak: \$0.1120 per kilowatt-hour (kWh).
Off-peak: \$0.0710 per kWh.

Power Cost Adjustment Clause: Charge per all kWh varies monthly. See schedule PCAC.

Prompt Payment of Bills: Same as Rg-1.

Minimum Monthly Bill: The minimum monthly bill shall be equal to the customer charge, plus the distribution demand charge.

Pricing Periods: On-peak: 8:00 a.m. to 8:00 p.m., Monday through Friday, excluding holidays, specified below.

Off-peak: All times not specified as on-peak including all day Saturday and Sunday, and the following holidays: New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day, and Christmas Day, or the day designated to be celebrated as such.

(Continued on next page)

Public Service Commission of Wisconsin

CITY OF EVANSVILLE WATER & LIGHT

Small Power Service – Optional Time of Day Service

Discounts: The monthly bill for service will be subject to the following discounts applied in the sequence listed below.

Primary Metering Discount: Customers metered on the primary side of the transformer shall be given a 1.25 percent discount on the monthly energy charge, distribution demand charge, and demand charge. The PCAC and the monthly customer charge will not be eligible for the primary metering discount.

Transformer Ownership Discount: Customers who own and maintain their own transformers or substations shall be given a credit of \$0.15 per kW of distribution demand. Customer-owned substation equipment shall be operated and maintained by the customer. Support and substation equipment is subject to utility inspection and approval.

Determination of Maximum Measured Demand: The Maximum Measured Demand in any month shall be that demand in kilowatts necessary to supply the average kilowatt-hours in 15 consecutive minutes of greatest consumption of electricity during each month. Such Maximum Measured Demand shall be determined from readings of permanently installed meters or, at the option of the utility, by any standard methods or meters. Said demand meter shall be reset to zero when the meter is read each month. The Maximum Measured Demand that occurs during the On-peak period shall be the On-peak Maximum Demand.

Determination of On-peak Billed Demand: The Maximum Measured Demand that occurs during the On-peak period shall be the On-peak Billed Demand.

Determination of Distribution Demand: The Distribution Demand shall be the highest monthly Maximum Measured Demand occurring in the current month or preceding 11-month period.

CITY OF EVANSVILLE WATER & LIGHT

Large Power Time of Day Service

Application: This rate will be applied to customers for all types of service, if their monthly Maximum Measured Demand is in excess of 200 kilowatts (kW) per month for three or more months in a consecutive 12-month period, but not greater than 1000 kW per month for three or more months in a consecutive 12-month period.

Customers billed on this rate shall continue to be billed on this rate until their monthly Maximum Measured Demand is less than 200 kW per month for 12 consecutive months.

Customer Charge: \$150.00 per month.

Distribution Demand Charge: \$1.75 per kW of distribution demand.

Demand Charge: \$8.75 per kW of on-peak billed demand.

Energy Charge: On-peak: \$0.0975 per kilowatt-hour (kWh).
Off-peak: \$0.0692 per kWh.

Power Cost Adjustment Clause: Charge per all kWh varies monthly. See schedule PCAC.

Minimum Monthly Bill: The minimum monthly bill shall be equal to the customer charge, plus the distribution demand charge.

Prompt Payment of Bills: Same as Rg-1.

Pricing Periods:

On-peak: 8:00 a.m. to 8:00 p.m., Monday through Friday, excluding holidays, specified below.

Off-peak: All times not specified as on-peak including all day Saturday and Sunday, and the following holidays: New Year’s Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day, and Christmas Day, or the day nationally designated to be celebrated as such.

(Continued on next page)

CITY OF EVANSVILLE WATER & LIGHT

Large Power Time of Day Service

Discounts: The monthly bill for service will be subject to the following discounts applied in the sequence listed below.

Primary Metering Discount: Customers metered on the primary side of the transformer shall be given a 1.25 percent discount on the monthly energy charge, distribution demand charge, and demand charge. The PCAC and the monthly customer charge will not be eligible for the primary metering discount.

Transformer Ownership Discount: Customers who own and maintain their own transformers or substations shall be given a credit of \$0.15 per kW of distribution demand. Customer-owned substation equipment shall be operated and maintained by the customer. Support and substation equipment is subject to utility inspection and approval.

Determination of Maximum Measured Demand and On-peak Maximum Demand: The Maximum Measured Demand in any month shall be that demand in kilowatts necessary to supply the average kilowatt-hours in 15 consecutive minutes of greatest consumption of electricity during each month. Such Maximum Measured Demand shall be determined from readings of permanently installed meters or, at the option of the utility, by any standard methods or meters. Said demand meter shall be reset to zero when the meter is read each month. The Maximum Measured Demand that occurs during the On-peak period shall be the On-peak Maximum Demand.

Determination of Distribution Demand: The Distribution Demand shall be the highest monthly Maximum Measured Demand occurring in the current month or preceding 11-month period.

Determination of On-peak Billed Demand: On-peak Billed Demand shall be the On-peak Maximum Demand.

Public Service Commission of Wisconsin

CITY OF EVANSVILLE WATER & LIGHT

Industrial Power Time-of-Day Service

Application: This rate will be applied to customers for all types of service if their monthly Maximum Measured Demand is in excess of 1000 kilowatts (kW) per month for three or more months in a consecutive 12-month period.

Customers billed on this rate shall continue to be billed on this rate until their monthly Maximum Measured Demand is less than 1000 kW per month for 12 consecutive months.

Customer Charge: \$200.00 per month.

Distribution Demand Charge: \$2.00 per kW of distribution demand.

Demand Charge: \$10.00 per kW of on-peak billed demand.

Energy Charge: On-peak: \$0.0906 per kilowatt-hour (kWh).
Off-peak: \$0.0660 per kWh.

Power Cost Adjustment Clause: Charge per all kWh varies monthly. See schedule PCAC.

Minimum Monthly Bill: The minimum monthly bill shall be equal to the customer charge, plus the distribution demand charge.

Prompt Payment of Bills: Same as Rg-1.

Pricing Periods:

On-peak: 8:00 a.m. to 8:00 p.m., Monday through Friday, excluding Holidays, specified below.

Off-peak: All times not specified as on-peak including all day Saturday and Sunday, and the following holidays: New Year’s Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day, and Christmas Day, or the day nationally designated to be celebrated as such.

(Continued on next page)

CITY OF EVANSVILLE WATER & LIGHT

Industrial Power Time-of-Day Service

Discounts: The monthly bill for service will be subject to the following discounts applied in the sequence listed below:

Primary Metering Discount: Customers metered on the primary side of the transformer shall be given a 1.25 percent discount on the monthly energy charge, distribution demand charge, and demand charge. The PCAC and the monthly customer charge will not be eligible for the primary metering discount.

Transformer Ownership Discount: Customers who own and maintain their own transformers or substations shall be given a credit of \$0.15 per kW of distribution demand. Customer-owned substation equipment shall be operated and maintained by the customer. Support and substation equipment is subject to utility inspection and approval.

Determination of Maximum Measured Demand and On-peak Maximum Demand: The Maximum Measured Demand in any month shall be that demand in kilowatts necessary to supply the average kilowatt-hours in 15 consecutive minutes of greatest consumption of electricity during each month. Such Maximum Measured Demand shall be determined from readings of permanently installed meters or, at the option of the utility, by any standard methods or meters. Said demand meter shall be reset to zero when the meter is read each month. The Maximum Measured Demand that occurs during the On-peak period shall be the On-peak Maximum Demand.

Determination of Distribution Demand: The Distribution Demand shall be the highest monthly Maximum Measured Demand occurring in the current month or preceding 11-month period.

Determination of On-peak Billed Demand: On-peak Billed Demand shall be the On-peak Maximum Demand.

Public Service Commission of Wisconsin

CITY OF EVANSVILLE WATER & LIGHT

Street & Yard Lighting Service

Application: This schedule will be applied to municipal and non-municipal street and yard lighting. The utility will furnish, install, and maintain street lighting units.

This rate schedule is closed to new mercury vapor lights.

Investment charge:

Overhead:

175 W MV	\$7.50 per lamp per month
400 W MV	\$8.00 per lamp per month
100 W HPS	\$7.50 per lamp per month
150 W HPS	\$8.00 per lamp per month
250 W HPS	\$8.50 per lamp per month
300 W LED	\$7.50 per lamp per month
≤100 W LED	\$10.50 per lamp per month
≤100 W LED Contributed*	\$7.50 per lamp per month
>100 W LED	\$11.50 per lamp per month

Ornamental:

Single Lamp Fixture, with Concrete Pole

175 W MH	\$11.50 per lamp per month
----------	----------------------------

Single Lamp Fixture, with Historic Cast Iron Pole**

175 W MH	\$13.00 per lamp per month
150 W HPS	\$12.50 per lamp per month
250 W HPS	\$13.00 per lamp per month
≤100 W LED	\$15.50 per lamp per month
>100 W LED	\$16.50 per lamp per month

Yard Lighting:

175 W MV	\$7.50 per lamp per month
250 W MV	\$7.50 per lamp per month
400 W MV	\$7.75 per lamp per month
100 W HPS	\$7.50 per lamp per month
150 W HPS	\$7.60 per lamp per month
250 W HPS	\$8.25 per lamp per month
≤100 W LED	\$9.00 per lamp per month
>100 W LED	\$10.00 per lamp per month

Business District Lighting:

1500 W MH	\$20.00 per lamp per month
-----------	----------------------------

(Continued on next page)

RATE FILE

Sheet No. 2 of 2

Public Service Commission of Wisconsin

Schedule No. Ms-1

Amendment No. 89

CITY OF EVANSVILLE WATER & LIGHT

Street & Yard Lighting Service

Energy Charge: \$0.0710 per kilowatt-hour (kWh).

Power Cost Adjustment Clause: Charge per all kWh varies monthly. See schedule PCAC.

Prompt Payment of Bills: Same as Rg-1.

*LED bar 100% Contributed by municipality

** Historic Ornamental Lighting Installations require a customer contribution equal to the material cost of the pole luminaire, etc. This is reflected in the above rate (Lights of this type were first installed in 1992)

Note:

MH = Metal Halide

MV = Mercury Vapor

LED = Light Emitting Diode

HPS = High Pressure Sodium

EFFECTIVE: August 31, 2023

PSCW AUTHORIZATION: Final Decision in Docket 1880-ER-107

RATE FILE

Sheet No. 1 of 1

Public Service Commission of Wisconsin

Schedule No. Ms-2

Amendment No. 89

CITY OF EVANSVILLE WATER & LIGHT

Athletic Field Lighting Service

Application: This schedule will be applied to municipal athletic field lighting. The utility will furnish, install, and maintain lighting units.

This rate schedule is closed to new mercury vapor lights.

Customer Charge: \$285.00 per month.

Energy Charge: \$0.0710 per kilowatt-hour (kWh).

Minimum Monthly Bill: The minimum monthly bill shall be the customer charge.

Power Cost Adjustment Clause: Charge per all kWh varies monthly. See schedule PCAC.

Prompt Payment of Bills: Same as Rg-1.

Time of Use of Lighting Units: The manager of the athletic field will at all times confer with the utility superintendent regarding the operation of the athletic field lighting units so the light will not be turned on during a time of peak demand.

Maintenance: The utility will maintain the lighting facilities and replace the lamps as necessary, billing the city for actual cost of materials and labor.

CITY OF EVANSVILLE WATER & LIGHT

Other Charges and Billing Provisions

Budget Payment Plan: A budget payment plan, which is in accordance with Wis. Admin. Code ch. PSC 113, is available from the utility. The utility does not use a fixed budget year. The utility will calculate the monthly budgeted amount by spreading the estimated annual bill over 11 months, with the last month consisting of any end of year adjustments.

Reconnection Billing: All customers whose service is disconnected in accordance with the disconnection rules as outlined in Wis. Admin. Code ch. PSC 113, shall be required to pay a reconnection charge. The charge shall be **\$40.00** during regular office hours. After regular office hours the minimum reconnection charge of **\$40.00** applies plus any overtime labor costs, not to exceed a total maximum charge of **\$100.00**.

Reconnection of a Seasonal Customer’s Service: Reconnection of a service for a seasonal customer who has been disconnected for less than one year shall be subject to the same reconnection charges outlined above. A seasonal customer shall also be charged for all minimum bills that would have been incurred had the customer not temporarily disconnected service.

Payment Not Honored by Financial Institution Charge: The utility shall assess a **\$25.00** charge when a payment rendered for utility service is not honored by the customer’s financial institution. This charge may not be in addition to, but may be inclusive of, the water utility’s insufficient fund charge when the check was for payment of both electric and water service.

Average Depreciated Embedded Cost: The embedded cost of the distribution system (excluding the standard transformer and service facilities), for each customer classification, is determined based on methodology authorized by the Public Service Commission of Wisconsin, and described in the utility’s Electric Rules. The average depreciated embedded cost by customer classification is as follows:

Residential Service: **\$600.38**.

Apartment and Rental Units Separately Metered: **\$600.38** per unit metered.

Subdividers and Residential Developers: **\$600.38** per unit.

General Service: (Including Multi-Unit Dwellings If Billed on One Meter): **\$1163.53**.

Power Service: **\$202.89** per kW (Cp-1), **\$131.82** per kW (Cp-2), **\$16.05** per kW (Cp-3), of average billed demand

Street Lighting: **\$27.98**.

EVANSVILLE WATER & LIGHT

New Load Market Pricing Service

1. Effective In

All territories served by the Utility.

2. Eligibility

Available to existing and new customers that would not expand load or take service from the Utility absent this New Load Market Pricing (NLMP) Service to include: (A) any existing customer with a Maximum Measured Demand in excess of 200 kW for 3 or more months in a consecutive 12 month period and an expected electric demand growth of at least 400kW or (B) a new customer with an expected peak demand of at least 400 kW.

An existing customer shall state that this NLMP Service was a factor in its decision to expand load with the Utility, and a new customer shall state that this NLMP Service was a factor in its decision to take service with the Utility.

This NLMP Service is only available to customers that (A) have informed the Utility at least 3 months prior to receiving service., (B) have electric meters that record 15 minute interval load data prior to the commencement of service hereunder, (C) will be billed on a calendar month basis, (D) have completed an application for participation under the NLMP Service and received approval from the Utility (an “Approved Application”) and (E) have had an energy efficiency assessment completed by a Focus on Energy Advisor within 12 months prior to taking service or agree to have an energy efficiency assessment completed by a Focus on Energy Advisor within six months after taking service.

A customer under this NLMP Service shall maintain a minimum of 400 kW of incremental demand for eight out of the twelve months in each year of the contract. Failure to meet this criterion will result in the customer being removed from this service. For purposes of eligibility, incremental demand is:

- For an existing customer that is expanding, the customer’s total demand purchased from the Utility minus the Demand Baseline Levels defined below.
- For a new customer, the customer’s total demand purchased from the Utility for the applicable month.

This NLMP Service is not available to customers transferring existing load from any other electric utility provider in Wisconsin to the Utility.

This NLMP Service is available to eligible customers on a first-come, first-served basis up to a maximum eligible load of 10 MW per customer, provided that (A) there is sufficient unsubscribed capacity available to the Utility under the WPPI Wholesale Sale of Electricity Requirements for

EVANSVILLE WATER & LIGHT

New Load Market Pricing Service
--

Eligible Load Growth wholesale schedule (the “WPPI NLMP Schedule”), and (B) WPPI Energy, the Utility’s wholesale electricity supplier (“WPPI”), approves such service on a first-come, first-served basis. Service under the NLMP must commence no later than 3 months after the date the Approved Application is signed by the customer and the Utility.

3. Term

Service under the NLMP is for a single term of four (4) consecutive years from the commencement of service on the first day of the month specified in an Approved Application. A customer may terminate service on the annual anniversary date of the NLMP Service as long as the customer provides at least 30 days’ written notice to the Utility. Upon termination, the customer will return to service under an applicable rate for which it is eligible under the utility’s service. A customer who terminates service or is removed may not return to the NLMP Service.

4. Rate

The eligible electric consumption for this NLMP Service is the amount of customer electric consumption above the customer’s Monthly Baseline Demand Level and Monthly Baseline Energy Levels (defined below). The standard applicable retail service rates shall apply for customer electric consumption up to and including its Baseline Demand Level and Baseline Energy Levels and amounts above the Baseline Demand Level and Baseline Energy Levels will be subject to the charges and rates defined below.

A. **Administrative Charge:** \$150.00 per month

B. **Incremental Demand Rate:**

If the customer’s monthly peak demand exceeds the Baseline Demand Level for the month, utility will charge the customer for the monthly peak demand less the Baseline Level (i.e., the “Incremental Demand”) at the following monthly fixed costs charged to the Utility by WPPI to provide service to the customer under the NLMP Service. These costs are a pass through of charges from the Midcontinent Independent System Operator, Inc. (“MISO”) and generally include, but are not limited to the following:

1. MISO Resource Adequacy charge based on the applicable MISO LRZ clearing price and accounting for MISO’s reserve margin requirement [applies only to firm load];
2. MISO Network Integration Transmission Service charge (actual previous year average per unit cost incurred by WPPI load); per kW of Incremental Demand
3. Other fixed transmission and ancillary service costs
 - a. MISO Schedule 1: Scheduling, System Control & Dispatch;
 - b. MISO Schedule 2: Reactive Supply & Voltage Control;

EVANSVILLE WATER & LIGHT

New Load Market Pricing Service
--

- c. MISO Schedule 10: MISO Cost Adder;
- d. MISO Schedule 10-FERC: FERC Annual Charges;
- e. MISO Schedule 11: Wholesale Distribution Service;
- f. MISO Schedule 26: Network Upgrade Transmission Expansion Charge;
- g. MISO Schedule 33: Blackstart Service;
- h. MISO Schedule 43: System Support Resources; and
- i. Direct Network Upgrade Charges (if any)

A multiplication factor to account for distribution loss and applicable gross receipts taxes will be applied to the Incremental Demand Rate calculated from the above components as further described below. In addition, a 1.02 multiplication factor will be applied to the Incremental Demand Rate calculated from the above components to account for transmission losses.

The MISO Resource Adequacy charge will only apply to firm load, and customers taking service on an interruptible basis will not incur that component of the Incremental Rate.

C. Incremental Energy Rate:

If the customer's energy consumption exceeds the Monthly Baseline Energy Level (on-peak or off-peak, as applicable) in any hour of the billing month, the Utility will charge the customer for the hourly energy consumption less the Monthly Baseline Energy Level (i.e., the "Incremental Hourly Energy") at the following energy costs charged to the Utility by WPPI to provide service to the customer under the NLMP Service. Except for the margin on energy, these costs are a pass through of charges from MISO and generally include, but are not limited to the following:

1. MISO Energy Costs:
 - a. Day-Ahead Hourly Locational Marginal Price (LMP) at applicable MISO CPNode per kWh of Incremental Hourly Energy (currently "WEC.WPPI" for the Utility)
 - b. Day-Ahead RSG Distribution Amount
 - c. Real-Time Demand Response Uplift Charge
 - d. Real-Time Distribution of Losses Credit
 - e. Real-Time MVP Distribution Amount
 - f. Real-Time Neutrality Uplift Amount
 - g. Real-Time RSG First Pass Distribution Amount
2. MISO Market Administration:
 - a. Schedule 17: Day-Ahead and Real-Time Market Administration Amount
 - b. Schedule 24: Control Area Operator Cost Recovery
3. MISO Ancillary Services:

EVANSVILLE WATER & LIGHT

New Load Market Pricing Service

- a. Schedule 3: Regulation Cost Distribution Amount
- b. Schedule 5: Spinning Reserve Cost Distribution Amount
- c. Schedule 6: Supplemental Reserve Cost Distribution Amount
- 4. MISO Transmission:
 - a. Schedule 10: MISO Cost Adder
 - b. Schedule 26: Multi-Value Project Cost Recovery
- 5. Adder on Energy at \$0.0005/kWh

A multiplication factor to account for distribution loss and applicable gross receipts taxes will be applied to the Incremental Energy Rate calculated from the above components as further described below.

The minimum Incremental Energy Rate billed shall not be less than \$0.007 / kWh in any hour.

D. Incremental Distribution Demand Rate:

A distribution demand billing option will be selected by the customer for the contract term as the Incremental Distribution Demand Rate for demand above the Baseline Distribution Demand Level (defined below) as follows:

- 1. Option 1 – Distribution Demand above the Baseline Distribution Demand Level will be subject to the same Distribution Demand charges applied to demand up to the Baseline Distribution Demand Level. A customer that selects Option 1 will receive a construction allowance per the Utility’s Electric Rules.
- 2. Option 2 – Distribution Demand above Baseline Distribution Demand Level will not be subject to the Distribution Demand charges applied to demand up to the Baseline Distribution Demand Level. A customer that selects this Option 2 will not receive a construction allowance per the Utility’s Electric Rules.

5. Monthly Baseline Demand Levels and Monthly Baseline Energy Levels for Existing Customers

Each existing customer’s Monthly Baseline Demand Level and Monthly Baseline Energy Levels shall be based on the most recent available historical 12 consecutive month time period (i.e., the “Baseline Period”) preceding the date of an Approved Application. Historical electric consumption patterns and demand levels experienced during the Baseline Period make up Monthly Baseline Demand Levels and Monthly Baseline Energy Levels that are to be used for billing for the duration of the applicable term of the NLMPService. These levels are to be determined prior to beginning service and will remain constant throughout the term of service.

EVANSVILLE WATER & LIGHT

New Load Market Pricing Service

Specifically, baseline levels will be established for monthly demand and monthly on- and off-peak energy as each of the following:

- Average hourly on-peak energy consumption by month for each of the twelve months preceding an Approved Application (“Monthly On-Peak Baseline Energy Level”);
- Average hourly off-peak energy consumption by month for each of the twelve months preceding an Approved Application (“Monthly Off-Peak Baseline Energy Level”);
- Firm on-peak demand by month for each of the twelve months preceding an Approved Application (“Monthly Baseline Demand Level”); and

The baseline 12-month ratcheted customer demand (the “Baseline Distribution Demand”) will remain the same over the entire term of NLMP service and will be equal to the Distribution Demand applicable in the month immediately preceding the date of an Approved Application.

Adjustments to the historical consumption patterns may be made by the Utility to eliminate data anomalies in the Baseline Period that are not expected to reoccur, or to accommodate unique production patterns as demonstrated in the historical data from the 24 months preceding the date of an Approved Application (e.g. if production is commonly reduced during a specific day of the week for maintenance shutdown).

6. Baseline Demand Levels and Baseline Energy Levels for New Customers

Baseline Demand Levels and Baseline Energy Levels for new customer accounts with less than 12 months of history will be based on a forecast, supplied by the new customer and reasonable to the Utility, of electric energy consumption and demand for the new facility. If applicable, the new customer must demonstrate how the new facility differs from prior facilities served by the Utility such that consumption patterns or levels at the new facility are dissimilar to that of past facilities. Corporate name changes, change in ownership of a facility or a corporation, the formation of subsidiaries, or similar actions will not qualify a customer as a new customer for purposes of determining the Baseline Demand Levels and Baseline Energy Levels.

Baseline Demand Levels and Baseline Energy Levels for new customers require approval by the Utility and will be no less than 70 percent of the forecasted demand and energy consumption for year one of service under this NLMP Service. After year one, the original Baseline Levels will be adjusted to new Baseline Levels for the remainder of the contract term to reflect the percentage of actual electric consumption in year one, rather than the percentage of the original forecast of year one consumption. For example, if the initial Baseline Level agreed upon for a specific month was at 70 percent of the year one energy forecast and that forecast was 1,000 MWh, then the initial Baseline would reflect 700 MWh. If actual consumption in that month of year one turned out to

EVANSVILLE WATER & LIGHT

New Load Market Pricing Service

be 1,100 MWh, the Baseline would then be adjusted for that month in the remaining years of the contract term to reflect 70 percent of 1,100 MWh, which equates to 770 MWh.

The Baseline Distribution Demand will be equal to zero for the entire term of NLMP service.

7. Energy Reductions Measures and Baseline Levels

For existing customers and new customers in the second and subsequent years of service under this schedule, the Baseline may be adjusted to reflect a systematic and permanent change in Customer production levels as a result of the implementation of energy efficiency, conservation, and process improvement measures, or through the installation of new equipment as these measures relate to the Baseline. The Customer must request a review of their historical Baseline period and provide the Utility with supporting documentation, which in the judgement of the Utility, after its review and verification indicates that the reduction is permanent and due to the aforementioned measures. This adjustment will not take effect until the beginning of the billing period following the execution of an amended contract. Baseline adjustments upon Customer request and pursuant to this condition will not occur more than once in a 12-month period.

8. Distribution Loss Multiplication Factor

The following table defines the Distribution Loss Multiplication Factor for customers under this NLMP Service:

	Multiplication Factor
Interconnection Voltage Greater than or equal to 100 kV	1.00
Interconnection Voltage Greater than 12 kV and Less than 100 kV	1.02
Interconnection Voltage Less than 12 kV	1.03

9. Gross Receipts Taxes Multiplication Factor

A Gross Receipts Taxes Multiplication Factor of 1.0319 times the total bill shall apply to applicable customer load served under this NLMP Service and located outside the municipal boundaries of the Utility.

EVANSVILLE CITY OF WATER & LIGHT

Shared Savings (Limited Participation)

Purpose and Availability

Available to customers served under Rate Schedules Gs-1, Gs-2, Cp-1, Cp-1 TOD, Cp-2 and Cp-3 who implement eligible energy efficiency projects, meet applicable credit requirements and enter into a Shared Savings agreement with the utility. The principal focus of the program is eligible projects where advance utility payment for energy cost savings to the customer is \$50,000 or less. In limited circumstances, and on a case-by-case basis, the utility may at its discretion make advance payments of up to \$500,000 for eligible customer expansion projects or new customer projects.

Application

Under this program, the utility will contribute an advance payment for energy cost savings related to energy efficiency projects to eligible retail customers. The amount of the advance payment will be based on energy savings achieved over a 60 month period, capped at the lesser of the project cost or the maximum advance payment per customer identified as follows:

1. For projects other than new customers or expansion projects noted below, the maximum advance payment for energy cost savings is \$50,000 per customer.
2. For new customers or existing customers that are expanding where the new customer's load or the existing customer's expansion is expected to be greater than or equal to 200 kW, the maximum advance payment for energy cost savings is \$500,000 per customer.

WPPI Energy capital will be used to underwrite this program and advance payments for energy cost savings are subject to the availability of WPPI Energy capital allotted to this program.

The customer will repay the advance payment in installments on the customer's retail electric bill over a term of up to 60 months at a 2% annual interest rate. WPPI Energy will recover the same installments from the utility on its wholesale power bill.

Terms and Conditions

1. Customer must complete a Shared Savings application which is subject to the approval of the utility and WPPI Energy.
2. Customer must pass a credit review.
3. Customer must enter into a contract with the utility.
4. Projects must reduce electric use and/or demand for the duration of the repayment period.
5. Projects must meet all minimum efficiency requirements. Minimum efficiency requirements will be aligned with those set forth by the Wisconsin Focus on Energy program.

(Continued on next page)

RATE FILE

Sheet No. 2 of 2

Schedule No. SS

Amendment No. 81

Public Service Commission of Wisconsin

EVANSVILLE CITY OF WATER & LIGHT

Shared Savings (Limited Participation) (Continued)

6. The customer applying must agree with all Shared Savings requirements relevant to the installation of the project equipment, including the right of the utility to have the equipment removed at the expense of the customer in the event of default.
7. Upon completion, the customer will submit a Certificate of Project Completion form to the utility.

CITY OF EVANSVILLE WATER & LIGHT

Commitment to Community Program Rider

Under provisions of 1999 Wisconsin Act 9 and 2005 Wisconsin Act 141, a municipal electric utility shall charge each customer a low-income assistance and energy efficiency fee. Fifty percent of the fees charged by the municipal utility shall be used for low-income assistance programs and the remainder will be used for energy efficiency programs. Low-income programs may include assistance to low-income households for weatherization and other energy conservation services, payment of energy bills or early identification or prevention of energy crises. Energy efficiency programs may include those programs designed to reduce the demand for natural gas or electricity or improving the efficiency of its use during any period.

Pursuant to Wis. Stats. §§ 16.957(5) and 196.374(7), each municipal electric utility must collect an average of \$16 per meter per year. The actual amount of fees paid by a customer cannot exceed the lesser of 3 percent of all other billed electric charges or \$750 per month. These fees are not subject to Gross Receipts or Sales Taxes. A municipal utility may determine the amount that a particular class of customers is required to pay and may charge different fees to different classes of customers.

Evansville Water & Light, in compliance with these laws and, as of the “Effective Date” established below, has set the fees for each retail electric customer rate classification as follows:

Rg-1 Residential Service	3.0% of the total electric bill not to exceed \$1.00
Rg-2 Residential Service Optional TOD	3.0% of the total electric bill not to exceed \$1.00
Gs-1 General Service	3.0% of the total electric bill not to exceed \$2.50
Gs-2 General Service Optional TOD	3.0% of the total electric bill not to exceed \$2.50
Cp-1 Small Power Service	3.0% of the total electric bill not to exceed \$15.00
Cp-1 Small Power Service Optional TOD	3.0% of the total electric bill not to exceed \$15.00
Cp-2 Large Power Service	3.0% of the total electric bill not to exceed \$15.00
Cp-3 Industrial Power Service	3.0% of the total electric bill not to exceed \$15.00
Ms-1 Street Lighting Service	No Charge
Ms-2 Athletic Field Lighting Service	No Charge

Questions regarding low-income assistance and energy efficiency fees or Evansville Water & Light’s Commitment to Community Programs should be directed to Evansville Water & Light at (608) 822-2280.

EVANSVILLE WATER & LIGHT

Renewable Energy Rider

Availability: Service under this rider is available to all customers currently served under all rate schedules. This rider allows customers the option of purchasing blocks of their energy from renewable resources.

Application: Renewable energy will be sold only in blocks of 300 kWh per month. Customers choosing to be served under this rider will pay the Block Charge for Renewable Energy in addition to the regular monthly charges, including the Power Cost Adjustment Clause, under their current applicable rate schedules. All of the provisions of the current applicable rate will apply to the customer’s total usage. The charge for renewable energy will be as stated below:

Block Charge for Renewable Energy:

\$2.00 per 300 kWh block of renewable energy per month for less than 20 blocks per month.
\$1.00 per 300 kWh block of renewable energy per month for 20 or more blocks per month.

Special Terms and Provisions:

1. Service under this rider may be limited at the sole discretion of the utility, based on the expected amount of renewable energy available, average monthly energy usage of the customer, bill payment and collection histories.
2. Aggregate sales are allowed only for multiple facilities owned by the same entity.
3. The customer may sign up for the program at any time and service will become effective at the beginning of the next full billing period, at which point the customer will be charged for the total number of blocks purchased. The Block Charge for Renewable Energy will not be prorated in the billing period in which a customer signs up for service under this rider.
4. If the customer uses less total energy than the number of blocks purchased in any given month, the customer will be charged for the total number of blocks purchased in that month.
5. The customer may cancel their service under this rider at any time; however, any change in service will only become effective at the beginning of the next full billing period. The Block Charge for Renewable Energy will not be prorated in the billing period in which the customer cancels.
6. The utility shall have on file a copy of the latest Schedule for Renewable Energy Service from its wholesale supplier.

Public Service Commission of Wisconsin

Schedule No. RER-2

Amendment No. 87

EVANSVILLE WATER & LIGHT

Industrial Renewable Energy Rider

This schedule is cancelled. All customers transferred to RER-1.

EFFECTIVE:

August 1, 2021

PSCW AUTHORIZATION:

Final Decision in Docket 1880-TE-104

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

Parallel Generation (20 kW or less) - Net Energy Billing

1. Effective In

All territories served by the utility.

2. Availability

Available for single-phase and three-phase customers where a part or all of the electrical requirements of the customer are supplied by the customer's generating facilities, where such facilities have a total generating capability of 20 kW or less, where such facilities are connected in parallel with the utility and where such facilities are approved by the utility.

3. Rate

The customer shall be billed monthly on a net energy basis, and shall pay the fixed charge and energy charge specified in the rate schedule under which he is served. If, in any month, the customer's bill has a credit balance of \$25 or less, the amount shall be credited to subsequent bills until a debit balance is reestablished. If the credit balance is more than \$25, the utility shall reimburse the customer by check upon request. Monthly credits shall be computed by taking the net excess kilowatt-hours produced times the sum of the applicable energy charge plus monthly power cost adjustment clause (PCAC).

4. Metering and Services Facilities

A customer who is served under a regular rate schedule shall have any ratchet and/or other device removed from his meter to allow reverse power flow and measurement of net energy used. Customers eligible for net energy billing but with existing metering facilities equipped with ratchets or other devices preventing reverse registration (i.e. time-of-use metering facilities) may request that the utility install the necessary metering to permit such billing.

5. Customer Obligation

See Pgs-2 Sections 10 and 11.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

Customer-Owned Generation Systems (Greater than 20 Kw)

1. Effective In

All territories served by the utility

2. Availability

Available for single-phase and three-phase customers where a part or all of the electrical requirements of the customer are supplied by the customer's generating facilities, where such facilities have a total generating capability of greater than 20 kW and less than or equal to 100 kW, where such facilities are connected in parallel with the utility. Customers not desiring to sell energy under this rate have the right to negotiate a buy-back rate.

The energy rate indicated below is the minimum for electrical energy. Customers with generating facilities greater than 100 kW can negotiate a buy-back rate. Should the utility be unwilling to pay the minimum rate for electrical energy, the utility shall agree to transport such electrical energy to another utility who will pay such minimum rate. The utility shall recover actual costs of such transportation from the generating customer.

3. Rate

Customers shall receive monthly payments for all electricity delivered to the utility and shall be billed by the utility for metering and associated billing expenses specified in the latest rates of the wholesale supplier unless the latest rates of the wholesale supplier do not properly reflect avoided costs. In such event, the Commission, upon request, may determine appropriate rates. The utility shall have on file a copy of the latest customer-owned generation system rates for its wholesale supplier.

4. On-Peak Hours, Off-Peak Hours and Holidays

On-peak hours and off-peak hours and holidays are those specified in the wholesale suppliers latest rates.

5. Minimum Charge

The monthly minimum charge paid by the customer shall be the customer charge.

6. Power Factor

The customer shall operate on a net power factor of not less than 90 percent.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

Customer-Owned Generation Systems (Greater than 20 kW) continued

7. Negotiated Rates

Customers with generation systems greater than 100 kW can negotiate a buy-back rate.

Customers with generation systems greater than 20 kW and less than or equal to 100 kW have the right to negotiate a buy-back rate. The buy-back rate can not be greater than the full avoided cost.

The following are the required procedure guidelines:

- a. The utility must respond to the customer-owned generating system within 30 days of the initial written receipt of the customer-owned generating system proposal and within 30 days of receipt of a subsequent customer-owned generating system proposal;
- b. The utility's rejection of the customer-owned generating system proposal must be accompanied by a counter-offer relating to the specific subject matter of the customer-owned generating system proposal; and
- c. If the utility is unable to respond to the customer-owned generating system proposal within 30 days it shall inform the customer-owned generating system of:
 - 1) Specific information needed to evaluate the customer-owned generating system proposal.
 - 2) The precise difficulty encountered in evaluating the customer-owned generating system proposal.
 - 3) The estimated date that it will respond to the customer-owned generating system proposal.
- d. The Commission may become involved in the utility negotiations upon showing by either utility or the customer-owned generating system that a reasonable conclusion cannot be reached under the above guidelines. The Commission may provide a waiver to the guidelines and order new negotiation requirements so that a reasonable conclusion can be reached.
- e. A copy of all negotiated buy-back rates shall be sent to the Commission. These rates shall not be effective until the contract is placed on file by the Commission.

8. Charges for Energy Supplied by the Utility

Energy supplied by the utility to the customer shall be billed in accordance with the standard applicable rate schedules of the utility.

Public Service Commission of Wisconsin**EVANSVILLE MUNICIPAL ELECTRIC UTILITY****Customer-Owned Generation Systems (Greater than 20 kW) continued**9. Maintenance Rate

A customer-owned generation facility may be billed lower demand charges for energy purchased during scheduled maintenance provided written approval is obtained in advance from the utility. Demand charges other than "Customer Demand" shall be prorated if maintenance is scheduled such that the utility does not incur additional capacity costs. Said probation shall be the demand charge times the number of authorized days of scheduled maintenance divided by the number of days in the billing period.

10. Contract Required

A contract is required between the utility and the customer-owned generation facility. The contract shall specify safety, system protection, and power quality rules that generators must comply with. The contract shall require a minimum of \$100,000 liability insurance or proof of financial responsibility for the customer-owned generation system. Contracts with customer-owned generation facilities selling energy under the standard (non-negotiated) rate have no specific term or length. Contracts with customer-owned generation facilities selling energy under a negotiated rate shall contain performance requirements and be of sufficient length to ensure the utility avoids the costs for which the customer-owned generation facility has been paid.

11. Customer Obligationa. Metering Facilities

The customer shall furnish, install and wire the necessary service entrance equipment, meter sockets, meter enclosure cabinets, or meter connection cabinets that may be required by the utility to properly meter usage and sales to the utility.

b. Interconnection Costs

The owner of the generating facility shall be required to pay all interconnection costs, including metering, incurred by the utility. Said costs, including financing costs, shall be paid by the owner within two years of the installation date of the interconnection facilities.

c. Liability Insurance

The owner of the generating facility shall be required to have liability insurance on the generating facility of at least \$100,000 or be able to prove financial responsibility.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

Customer-Owned Generation Systems (Greater than 20 kW) continued

d. Interconnection and Operation (Safety and Power Quality) Requirements

Electric Service to a customer-owned electric generation installation may be disconnected for failure to comply with these requirements.

- 1) Interconnection of a generating facility with the utility system shall not be permitted until application has been made to and approval received from the electric utility. The utility may withhold approval only for good reason such as failure to comply with applicable utility or governmental rules or laws. The utility shall require a contract specifying reasonable technical connection and operating aspects for the parallel generating facility.
- 2) The utility may require that for each generating facility there be provided between the generator or generators and the utility system, a lockable load-break disconnect switch. For installations interconnected at greater 600 volts a fused cutout switch may be substituted, where practicable. The switches shall be accessible to the utility for the purpose of isolating the parallel generating facility from the utility system when necessary.
- 3) The utility shall require a separate distribution transformer for a customer having a generating facility where necessary, for reasons of public and employee safety or where the potential exists for the generating facility causing problems with the service of other customers. Ordinarily the requirement should not be necessary for an induction-type generator with a capacity of 5 kW or less, or other generating units of 10 kW or less that utilize line-connected inverters.
- 4) Where necessary, to avoid the potential for a facility causing problems with the service of other customers, the utility should limit the capacity and operating characteristics of single-phase motors. Ordinarily single-phase generators should be limited to a capacity of 10 kW or less.
- 5) The utility shall require that each generating facility have a system for automatically isolating the generator from the utility's system upon loss of the utility supply, unless the utility desires that the local generation be continued to supply isolated load. For synchronous and induction generators such protection against continued operation when isolated from the utility system will ordinarily consist of over-current protection, fuse or circuit breaker, plus a voltage or frequency controlled contractor which would automatically disconnect the unit whenever its output voltage or frequency drifted outside predetermined limits, such as plus or minus 10 percent of the rated values.

Public Service Commission of Wisconsin**EVANSVILLE MUNICIPAL ELECTRIC UTILITY****Customer-Owned Generation Systems (Greater than 20 kW) continued**

Other suitable protective systems against abnormal voltages of frequencies may be accepted by the utility.

- 6) The utility shall require that the customer discontinue parallel generation operation when it so requests and the utility may isolate the generating installation from its system at times:
 - a) When considered necessary to facilitate maintenance or repair of utility facilities.
 - b) When considered necessary during system emergencies.
 - c) When considered necessary during such times as the generating facility is operating in a hazardous manner, or is operating such that it adversely affects service to other customers or to nearby communication systems or circuits.
- 7) The owner of the generating facility shall be required to make the equipment available and permit entry upon the property by electric and communication utility personnel at reasonable times for the purposes of testing isolation and protective equipment, and evaluating the quality of power delivered to the utility's system; and testing to determine whether the local generating facility is the source of any electric service or communication systems problems.
- 8) The power output of the generating facility shall be maintained such that the frequency and voltage are compatible with normal utility service and do not cause that utility service to fall outside the prescribed limits of Commission rules and other standard limitations.
- 9) The generating facility shall be operated so that variations from acceptable voltage levels and other service impairing disturbances do not result in adverse effects on the service or equipment of other customers, and in a manner which does not produce undesirable levels of harmonics in the utility power supply.
- 10) The owner of the generating facility shall be responsible for providing protection for the owner's installation equipment and for adhering to all applicable national, state and local codes. The design and configuration of certain generating equipment such as that utilizing line-commutated inverters sometimes requires an isolation transformer as part of the generating installation for safety and for protection of generating facilities.

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

Customer-Owned Generation Systems (Greater than 20 kW) continued

12. Utility Obligation

a. Metering Facilities

The utility shall install appropriate metering facilities to record all flows of energy necessary to bill in accordance with the charges and credits of the rate schedule.

b. Notice to Communication Firms

Each electric utility shall notify telephone utility and cable television firms in the area when it knows that customer-owned generating facility is to be interconnected with its system. This notification shall be as early as practicable to permit coordinated analysis and testing in advance of interconnection, if considered necessary by the electric or telephone utility or cable television firm.

13. Right to Appeal

The owner of the generating facility interconnected or proposed to be interconnected with a utility system may appeal to the Commission should any requirement of the utility service rules filed in accordance with the provisions of 113.70 or the required contract be considered to be excessive or unreasonable. Such appeal will be reviewed and the customer notified of the Commission's determination.

EVANSVILLE WATER & LIGHT

Solar Renewable Energy Distributed Generation (Limited Participation)

This rate schedule is closed to any new customers

Effective In

All territories served by the utility.

Availability

Available to customers who own small solar photovoltaic (PV) electric generating facilities that are approved by the Utility. Individual project nameplate rated capacity is limited to a maximum of 6 kW dc or the total PV generation nameplate capacity allowable under this tariff, whichever is less. Under this tariff, the total PV generation nameplate capacity for all the Utility’s participating customers shall be limited to a maximum capacity of 6 kW dc or, provided that there is sufficient unsubscribed PV capacity available under WPPI Energy’s Schedule for Purchase of Solar Photovoltaic Energy, the Utility’s total PV generation nameplate capacity may be increased by an amount not to exceed 18 kW dc.

Rates:

1. Metering Charge: **\$1.00** per month. This is in addition to any customer charge applicable under the retail tariff the customer is currently receiving service under. A separate meter is required to measure the electricity produced by the customer.
2. Energy Purchase Rate: The Utility will purchase 100% of the generator output from the customer. The Utility will then resell the PV energy to WPPI Energy. The PV generator’s output shall be measured separately from the customer’s usage. The energy buy-back rate provided under this tariff shall be equal to WPPI Energy’s wholesale PV energy buy-back rate as specified in WPPI Energy’s Schedule for Purchase of Solar Photovoltaic Energy in effect at the time the customer enters into a buy-back contract with the Utility. The customer will receive a monthly credit on their electric utility bill for the energy sold to the Utility at the above rate. The Utility shall maintain copies of each revision of WPPI Energy’s Schedule for Purchase of Solar Photovoltaic Energy with the Utility’s authorized tariffs.

(Continued on next page)

Public Service Commission of Wisconsin

EVANSVILLE WATER & LIGHT

Solar Renewable Energy Distributed Generation (Limited Participation)

Customer Obligation:

See Wis. Admin. Code ch. PSC 119

Utility Obligations:

1. Metering Facilities: The Utility shall install appropriate metering facilities to record all flows of energy necessary to bill in accordance with the charges and credits of the rate schedule.
2. Notice to Communication Firms: The Utility shall notify telephone utility and cable television firms in the area when it knows that a customer-owned generating facility will be interconnected with its system. This notification shall be as early as practicable to permit coordinated analysis and testing in advance of interconnection if considered necessary by the electric or telephone utility or cable television firm.

Terms and Conditions:

1. Contract Requirement: A ten (10) year contract is required between the Utility and the participating customer. The contract shall specify the energy buy back rate and any safety, system protection, and power quality terms or rules with which the generator(s) must comply. WPPI Energy shall obtain full rights to and own all Renewable Energy Credits and Attributes generated by the project(s).
2. Interconnection Requirements: Generation facilities must meet the interconnection requirements of the “Rules for Interconnecting Distributed Generation Facilities” (Wis. Admin. Code ch. PSC 119). Interconnection of the generator will be at service voltage only.
3. Distribution Outages: Under certain conditions, the distribution system may experience a short term failure and may not be able to accept output from PV generators. These events occur periodically and there will be no compensation to the customer, by the Utility or WPPI Energy, for energy that cannot be delivered to the utility during distribution outages.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

**GENERAL SERVICE AND EXTENSION RULES
TABLE OF CONTENTS**

<u>Section Number</u>	<u>Name</u>	<u>Sheet Number</u>
101	<u>CONTRACT PROVISIONS</u>	
101.1	Term of Contract.....	5
101.2	Definition and Classification of Customers.....	5
101.3	Application of Rates and Combined Metering	6
101.4	Availability of Service Voltages.....	7
101.5	Dual Voltages	8
101.6	Emergency Systems.....	8
	Application for Service.....	*
	Customer Deposits.....	*
	<u>BILLING</u>	
	Regular Billing.....	*
	Budget Payment Plan..... (See OC-1)	*
	Estimated Bill	*
	Billing for Fractional Month Service.....	*
	Failure of Meters to Register Properly.....	*
	Billing for Energy Lost Due to Grounds on Customer's Equipment.....	*
	Determination of Demand	*
	Diversion of Service	*
	<u>PAYMENT OF BILLS</u>	
	Late Payment Charge.....	*
	Disconnection and Refusal of Service	*
	Deferred Payment Agreement.....	*
	Notice of Disconnection	*
102	<u>OTHER PROVISIONS</u>	
102.1	Insufficient Fund Charge (See OC-1)	8
102.2	Reconnection Billing	8
102.3	Reconnection of a Seasonal Customer's Service..... (See OC-1)	8

*See ch. PSC 113, Wis. Adm. Code.

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

TABLE OF CONTENTS (continued)

Section Number	Name	Sheet Number
102	<u>OTHER PROVISIONS</u> (continued)	
102.4	Overbilling of Customers	8
	Access to Customer's Premises.....	*
	Continuity of Service.....	*
	Voltage Regulation	*
103	<u>DEFINITIONS OF DISTRIBUTION AND SERVICE FACILITIES</u>	
103.1	Overhead Service Drop.....	9
103.2	Underground Service Lateral.....	9
103.3	Distribution Facilities	9
103.4	Underground Service Extension.....	9
103.5	Service Entrance Equipment.....	9
103.6	Service Facilities.....	9
104	<u>UTILITY FACILITIES ON CUSTOMER'S PREMISES</u>	10
105	<u>CUSTOMER'S RESPONSIBILITY FOR UTILITY'S EQUIPMENT</u> ..	10
106	<u>EXTENSION OF NEW SERVICE FACILITIES</u>	
106.1	Application for Extension of New Service.....	11
106.2	Wiring Affidavit	11
106.3	Ownership of Extension	11
106.4	Right-of-way for Extensions.....	12
106.5	Construction Standards and Facilities Provided by Utility.....	12
106.6	Point of Termination.....	13
106.7	Meters	14
106.8	Metering Facilities	14
106.9	Number of Service Drops or Laterals Per Customer.....	14
106.10	Overhead Service Drop.....	15
106.11	Underground Service Lateral.....	15
106.12	Transformers.....	15
106.13	Nonstandard Service Facilities	16
106.14	Extraordinary Investment by Utility for Extension.....	16

*See ch. PSC 113, Wis. Adm. Code.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

TABLE OF CONTENTS (continued)

<u>Section Number</u>	<u>Name</u>	<u>Sheet Number</u>
107	<u>INSTALLATION CHARGES AND EMBEDDED COST CREDITS</u>	
107.1	Definitions of Equipment, Installation Charges and Embedded Cost Credits.....(See OC-1)	16
107.2	Total Cost of Installation by Customer Classifications	18
108	<u>REFUNDS OF CUSTOMER CONTRIBUTIONS BY TYPE OF CUSTOMER</u>	
108.1	Eligibility for Refunds	19
108.2	Application of the Refund	20
109	<u>OVERHEAD SERVICE EXTENSIONS</u>	
109.1	Applicability	20
109.2	Contributions for Overhead Extension	20
109.3	Combination Single-Phase and Three-Phase Construction	21
110	<u>UNDERGROUND SERVICE EXTENSIONS</u>	
110.1	General Rules on Underground Service Extensions.....	21
110.2	Stipulations on Availability of Underground Service Extension.....	21
110.3	Contributions for Underground Extensions.....	22
110.4	Contribution for Added Costs Due to Unusual Conditions	22
110.5	Combination of Overhead and Underground Extension.....	23
110.6	Underground Distribution Areas	23
111	<u>MODIFICATIONS TO EXISTING DISTRIBUTION AND SERVICE FACILITIES</u>	
111.1	Relocation and Rebuilding of Existing Distribution Facilities.....	26
111.2	Replacement of Overhead Distribution Facilities with Underground Distribution Facilities	26
111.3	Upgrade of Distribution Facilities Due to Change in Load	27
111.4	Upgrade of Service Facilities.....	27

*See ch. PSC 113, Wis. Adm. Code.

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

TABLE OF CONTENTS (continued)

<u>Section Number</u>	<u>Name</u>	<u>Sheet Number</u>
112	<u>EXTENSION OR MODIFICATION OF TRANSMISSION FACILITIES TO RETAIL CUSTOMERS</u>	28
113	<u>TEMPORARY SERVICE</u>	28
114	<u>TEMPORARY SERVICE FOR CONSTRUCTION</u>	29
115	<u>EMERGENCY SERVICE</u>	29
116	<u>GENERAL RULES ON CUSTOMER UTILIZATION EQUIPMENT</u> ..	30
117	<u>MOTORS AND MOTOR CONTROL</u>	31
118	<u>MISCELLANEOUS EQUIPMENT</u>	33
119	<u>PRIVATE POWER PLANTS</u>	33
120	<u>PAYMENT FOR CONTRIBUTION IN AID OF CONSTRUCTION</u> ...	34
	<u>GASEOUS TUBE LIGHTING</u>	*
	<u>ELECTRIC WELDERS</u>	*
121	<u>STRAY VOLTAGE SERVICE</u>	34

*See ch. PSC 113, Wis. Adm. Code.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

101 CONTRACT PROVISIONS

101.1 Term of Contract

All agreements for service shall be for a period of one year unless otherwise specified in the contract. Contracts are automatically renewed at the end of their term under conditions stated in the contract.

No agent or employee of the utility shall have the power to, or shall amend, modify, alter, or waive any of the rates or rules of the utility or bind the utility by making any representation not incorporated in the contract.

Contracts shall not be transferred unless authorized by the utility; new occupants of premises previously receiving service must make official application to the utility before commencing the use of service.

Customers who have been receiving service must notify the utility when discontinuing service; otherwise, they will be liable for the use of the service by their successors should said successors refuse to pay.

When entering into a contract to supply primary service, the utility will specify the voltage at which it will serve the customer's load up to a specified maximum measured demand, and the customer shall provide a substation of an appropriate size and design. Should the customer later desire to increase the size of his load above that specified in his contract, or change its character, a new contract for primary service will be entered into between the utility and the customer, in which case the utility may specify a higher voltage for service. In such cases the customer shall have the following options:

- A. Taking the added requirement at the higher voltage and maintaining the existing load at the present voltage. At the option of the utility, the customer may be billed on a conjunctive basis.
- B. Taking service at one point at the higher voltage, constructing a new high voltage station.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

101.2 Definition and Classification of Customers

An electric customer or unit of service shall consist of any contiguous aggregation of space or area occupied for a distinct purpose such as a residence, apartment, flat, store, farm, office, factory, etc., which is equipped with one or more fixtures for rendering service separate and distinct from other users. The public portions of buildings, such as hallways, toilets, etc., may be treated separately depending on the requirements.

Unless otherwise defined, the ultimate use of energy purchased by the customer(s) determines the rate schedule applicable to their installation. Electric customers in general may be classified as follows:

- Residential Customers
- General Service Customers
- Power Service Customers
- Public Street and Highway Lighting Customers
- Miscellaneous Customers

101.2 Definition and Classification of Customers (continued)

101.2a Residential Customers

A residential customer is defined to include each separate house, apartment, flat or other living quarters occupied by a person or persons constituting a distinct household and using energy for general household purposes. Lighting use may be extended to include the use of energy for lighting the land and buildings which are adjacent to, connected with, and used exclusively by the residence being served.

101.2b General Service Customers

A general service customer is defined to include each separate business enterprise, occupation or institution, taking service through a single meter, occupying for its exclusive use any unit or units of space such as an entire building, entire floor, suite of rooms or a single room, and using energy for general purposes as the schedule of rates applicable to the particular installation may permit.

101.2c Power Service Customers

A power service customer is defined to include each residence, separate business enterprise or institution occupying for its exclusive use, any unit or units of space, such as an entire building, entire floor, suite of rooms or a single room, and using energy for driving motors or other electrical loads larger than permitted on the utility's other rate schedules.

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

101.2d Public Street and Highway Lighting Customers

A public street or highway lighting customer is defined to include governmental agencies which take service for the purpose of lighting public streets, highways or traffic signs.

101.2f Miscellaneous Customers

Customers using electric service for purposes not included in the above classifications are defined as miscellaneous customers.

101.3 Application of Rates and Combined Metering

The schedules of rates apply when electricity is furnished in any month to one customer at one location for a class of service through one meter. The schedules of rates are based on delivery and billing service to the ultimate user for retail service and does not permit resale or distribution.

For all extensions of new or increased service, each unit must be separately metered before service will be rendered.

Where a customer occupies more than one unit of space, each unit will be metered separately and a separate bill will be computed and rendered based on the readings of each individual meter unless a customer makes arrangements with a utility to provide the approved circuits and loops by which the different units can be connected and all energy metered through one meter.

Where a commercial and one or more residential units are combined so as to obtain electric service through one meter, or where a customer occupies a building or apartment for residential and commercial purposes jointly, the customer shall be billed on a rate which is determined based on the customer's total load.

101.4 Availability of Service Voltages

Service may be taken at the following service voltages:

Singe-phase	120/240 volt 3 wire
Three-phase	208 volt 3-phase wye
	277/480 volt 3-phase wye
	2400 volt delta
	4160 volt grounded wye
	7200/12,400 volt grounded wye primary

Other specific voltages may be available, if approved by the utility.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

101.5 Dual Voltages

If a customer requires service at a voltage other than that offered by the utility or at more than one voltage, the customer shall furnish and maintain the additional equipment required. If the customer's service requires two or more transformer settings or points of delivery to a structure, the customer shall also furnish and maintain the additional equipment required.

101.6 Emergency Systems

Where emergency systems in buildings are so wired as to require a separate meter, the energy so metered will be billed as a separate customer. Emergency systems are systems supplying power and illumination essential to safety, life and property where such systems or circuits are legally required by municipal, state, federal or other codes, or by any governmental agency having jurisdiction.

Emergency illumination shall include only the required exit lights and other lights specified as necessary to provide sufficient illumination.

102 OTHER PROVISIONS

102.1 Insufficient Fund Charge (see Schedule OC-1)

102.2 Reconnection Billing (see Schedule OC-1)

102.3 Reconnection of a Seasonal Customer's Service (see Schedule OC-1)

102.4 Overbilling of Customers

In the event the utility becomes aware of an overbilling of a customer, the utility shall promptly correct the billing error and notify the customer of the circumstances surrounding the overbilling. The utility shall then determine the time period during which the overbilling occurred. In making this determination, the utility shall apply PSC rules and utility rules and tariffs.

Once the utility has determined the period of overbilling, the utility shall calculate the amount that it has overbilled the customer. The utility shall then make a refund to the customer of the amount of the overbilling, together with interest as calculated pursuant to ch. PSC 113, Wis. Adm. Code.

Except as otherwise provided in ch. PSC 113, Wis. Adm. Code, the maximum refund to the customer shall be for a time period not to exceed six years from the date the overbilling was discovered pursuant to s. 893.93(1)(a), Stats.

All overbilling disputes arising under this section shall be taken to the PSC for resolution.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

103 DEFINITION OF DISTRIBUTION AND SERVICE FACILITIES

103.1 Overhead Service Drop

The overhead service between the last pole or other aerial support of the distribution system and the point of attachment to the customer's service entrance equipment. It is normally located over the customer's property.

103.2 Underground Service Lateral

The underground service between the distribution system, including any risers at a pole or other structure, and the service entrance equipment. It is normally located on the customer's property.

103.3 Distribution Facilities

All primary and secondary voltage wire or cable and its supports, trenches, connection equipment, enclosures, and control equipment which is used to extend the distribution system from existing facilities to a point of connection with the service facilities. The cost of right-of-way preparation and restoration to the original condition where appropriate shall be included in the cost of distribution facilities.

103.4 Underground Service Extension

Consists of an underground service lateral and necessary distribution line, if any. In no case shall it consist of separate segments of underground construction separated by overhead construction. The length of each underground service extension shall be the length of the cable route from the beginning of the trench to the point of termination at the applicant's service facilities.

103.5 Service Entrance Equipment

Consists of the meter socket and related overhead masthead or conduit for underground service. This equipment is provided by the customer and is generally located on or in the customer's building.

103.6 Service Facilities

The standard transformer, standard overhead service drop or standard underground service lateral and standard meter.

(1.) For a customer receiving primary service, service facilities include the necessary metering equipment only.

U

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

104 UTILITY FACILITIES ON CUSTOMER'S PREMISES

This rule shall apply to the distribution facilities required to service either a group of customers in multi-tenancy premises or a single customer where, in either case, the utility finds that it is necessary to install portions of such facilities on the premises being served. Such customer or property owner, when requested by the utility, shall make provision on his property for the installation of utility-owned facilities required for service(s) in accordance with the following:

Utility facilities shall consist of those which, in the opinion of the utility, are necessary to furnish adequate service at the utility-owned junction boxes on or adjacent to the enclosure of the utility substation or at customer-owned service entrance facilities. The utility will not supply wiring in or on a building beyond the junction box or on a building beyond the service entrance facilities. The utility will design such installations and will install facilities, which in its opinion, are most economical or feasible to the utility, under the conditions met. At each installation the utility shall have the option of extending its primary conductors to two or more substations conveniently located with respect to the customers to be served or to furnish service to all customers from the substation. Where the utility's installation is located in a property owner's building, the applicable provisions of the Wisconsin State Electrical Code shall be observed.

A customer or property owner shall furnish, own and maintain the necessary indoor conduits, indoor or outdoor enclosures, vaults, building structural supports and accessories as specified by the utility.

If a customer or property owner requests any changes in the plan proposed by the utility, the customer shall pay the utility the estimated excess cost of the substituted installation. The utility may require that these costs be paid in advance of construction or may, at the utility's option, offer customers an installment payment plan.

105 CUSTOMERS' RESPONSIBILITY FOR UTILITY'S EQUIPMENT

The customer shall be responsible for all damage to the utility's equipment, and for all loss resulting from interference or tampering therewith, caused by the customer or the customer's permittees, including compensation for consumed energy not recorded upon the meter (see ch. PSC 113, Wis. Adm. Code.)

Meters, service entrance switches, and service entrance outlets are sealed by the utility and such seals shall not be broken or tampered with in any manner without the consent of the utility except in cases of emergency. The utility should be notified as soon as possible after a seal has been broken.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

106 EXTENSION OF NEW SERVICE FACILITIES

106.1 Application For Extension of New Service

Each request for extension of new service will require a written application for service in which the applicant agrees to pay any required contribution in aid of construction. The utility may require that the contribution in aid of construction be paid in advance of construction or may, at the utility's option, offer customers an installment payment plan.

106.2 Wiring Affidavit

The contractor or person responsible for the installation of the customer's electric wiring, appliances and other equipment related to each type of service shall deliver a notarized affidavit on a form supplied by the utility attesting to the fact that the work complies with the Wisconsin State Electrical Code and the service rules of the utility. Affidavits must clearly indicate the nature of the work done (such as residential wiring, residential fixtures, garage wiring, range, heaters, motors, or other wiring or equipment). For those cases involving wiring changes or additions which require the meter(s) to be replaced or relocated, or which require inspection by the utility, the affidavit shall include an itemized copy of the connected load, including lights, motors and appliances. Where such changes require new service entrances at a new location, the existing service entrance should not be disconnected before the new service entrance is ready for connection and operation.

If, upon inspection by the utility, installations are found to contain discrepancies, such discrepancies shall be corrected before permanent connection of service will be completed. Or, at its option, the utility may mail the customer a written request demanding conformity within a 10-day period or any prior service connection made by the utility will be disconnected.

The utility normally connects the service entrance wires to the service wires. No one else shall make these connections without the specific approval from the utility, in which case the customer shall assume responsibility for any damage which may result from making these connections. The utility will not be responsible for damage or injury resulting from unauthorized disconnection or reconnection of service wires.

106.3 Ownership of Extension

The title to every extension at all times is with the utility. The utility reserves the right at all times to add additional customers to an extension and make new extensions to an existing extension, under the provisions of these rules, without procuring the consent of any customer or customers contributing to the original construction costs, and without incurring any liability for refunding contributions except as additional customers may be added as provided for herein. (See ch. PSC 113, Wis. Adm. Code, Refunds.)

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

106.4 Right-of-way For Extensions

106.4a Overhead Facilities

The applicant(s) for service shall furnish right-of-way easements and permits with clearing rights, without cost to the utility adequate for the line extensions necessary to serve them and along a route approved by the utility. Clearing shall either:

- (1.) Be done by the applicant(s); or
- (2.) Be done by the utility. In this case, the applicant shall, in advance of the clearing work, make a contribution to the utility in an amount equal to the utility's estimate of the cost thereof. Such a contribution shall be nonrefundable, except that after completion of the extension the utility will determine the actual cost of clearing work, recompute the contribution required, and will refund the excess, if any, of the contribution over that required as based on such actual cost.

106.4b Underground Facilities

The applicant(s) shall secure for the utility, without cost to the utility, such easements as the utility may require for the installation, maintenance or replacement of the underground lateral and necessary distribution line extension.

The applicant shall inform the utility of any known or expected underground obstructions within the cable routes on his property (septic tanks, drainage tile, etc.). Any earth fill added to bring the cable route to final grade prior to the underground construction shall not contain large rocks, boulders, debris or rubbish.

In the event of future changes in grade levels by the customer that would materially change the depth of cover over underground conductors, or affect transformer locations, the landowner shall notify the utility in advance of grading, and shall pay the utility its cost of moving or replacing its equipment to accommodate the change in grade. Such charge will also be made for changes in buildings, structures, foundations, walls, or other obstructions.

106.5 Construction Standards and Facilities Provided by Utility

The utility shall provide safe, reliable service with extensions that conform, to the extent possible, to each of the following standards:

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

106.5 Construction Standards and Facilities Provided by Utility (continued)

- (1.) Route. The utility shall make the extension over the most direct route which is the least expensive and least environmentally degrading. The customer shall provide or shall be responsible for the cost of all right-of-way easements, and permits necessary for the utility to install, maintain or replace distribution facilities. The customer shall either clear and grade such property or pay the utility to clear and grade such property. The customer is responsible for the cost of restoration of the property after the utility has completed installation and backfilling where applicable.
- (2.) Design. The utility shall design and install facilities to deliver service to the customer and the area at the lowest reasonable cost. The facilities shall comply with accepted engineering and planning practices. The design shall consider reasonable needs for probable growth in the area and local land use planning. Unwarranted excess capacity which would result in unnecessary cost increases to the utility and its customers shall be avoided. The utility shall be responsible for the incremental cost of distribution facilities which are in excess of standard design for the customer and normal area growth.
- (3.) Efficient Use. The utility's extension rules shall discourage the inefficient use of electricity by appropriately relating costs to the charges made for extensions.
- (4.) Cost Estimates. The utility shall engineer and estimate the cost of each extension based on reasonable current costs. Current costs may be estimated using job specific costs, average costs per foot or unit, or other costing method as appropriate.

106.6 Point of Termination

The applicant for new service may select, with the approval of the utility, the point at which the utility will deliver service at applicant-owned terminating facilities. The applicant will furnish, own and maintain circuits, meter socket and equipment beyond such point, except for metering equipment.

It is necessary that a customer's service entrance facilities be located at a point most readily accessible to the utility's distribution system. It is desirable, and often necessary, to avoid crossing adjacent property with service drops or laterals. If the distribution system is established in the rear of the premises, the service entrance must be brought to the rear of the building. Where the distribution system is located on the street or where no distribution system has been established, the customer shall request the utility to specify an acceptable location of the service entrance facilities. The utility will furnish this information in writing upon request.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

106.7 Meters

Meters will be furnished and installed by the utility. The customer, however, must furnish the meter socket and all necessary extra wiring to meet the meter connection and must furnish a safe and convenient place for the meter(s).

In the event a customer desires an additional meter installed for their own convenience, the installation shall be entirely at the cost of the customer, including the cost of the meter.

106.8 Metering Facilities

Meter sockets shall be installed by the customer on the exterior of the building.

In rural areas, a yard pole may be furnished by the utility and located at a point central to the buildings to be served. The meter socket shall be installed by the customer on this pole. All service equipment beyond this point is the responsibility of the customer.

When only a residence is built in the rural area and underground service is used, the meter may be placed on the pole if permission is obtained from the utility prior to installation. A customer-owned yard light may not be installed on this pole unless permission is obtained from the utility. Any meter located other than as described above shall be approved in writing by the utility prior to installation or it shall be changed by the customer to conform to the utility standards.

106.9 Number of Service Drops or Laterals Per Customer

The utility shall provide standard overhead service drops and standard underground service laterals at no charge to the customers.

Not more than one service drop or service lateral will be installed to the same building or utilization point except:

- (1.) Where more than one point of delivery is necessary because of voltage regulation, governmental requirements or regulatory orders.
- (2.) In large installations (large power only) where, in the opinion of the utility, more than one service drop or lateral is necessary to meet the load requirements.
- (3.) In row houses and other multiple occupancy buildings having areas separated by fire walls in compliance with the Wisconsin State Electrical Code.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

106.9 Number of Service Drops or Laterals Per Customer (continued)

If an existing customer with a single-phase service drop or lateral requests three-phase service, the customer shall rewire his equipment to operate from the three-phase service drop or lateral before three-phase service will be extended. The single-phase service drop or lateral will be removed from service after the three-phase service has been extended.

106.10 Overhead Service Drop

A standard overhead service drop shall be furnished by the utility to a suitable support on the customer's premises. The utility will provide supplemental information to the customer indicating the equipment that the customer shall install, own and maintain. This material will also indicate what Wisconsin State Electric Code provisions and city ordinances must be complied with for the installation of this equipment.

106.11 Underground Service Lateral

A standard underground service lateral shall be furnished by the utility to suitable service equipment on the customer's premises. This equipment shall be installed on the customer's building at a location approved by the utility.

The utility will provide supplemental information indicating what equipment the customer shall install, own and maintain for underground service and indicate what provisions of the Wisconsin State Electric Code and city ordinances must be complied with for the installation of this equipment.

106.12 Transformers

The utility shall provide standard design transformers necessary to serve the customer's load at no charge.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

106.13 Nonstandard Service Facilities

If the proposed extension requires nonstandard service facilities or if the customer requests nonstandard facilities, the utility may require that the customer pay a contribution in advance of construction for the cost of the facilities in excess of the cost of standard design facilities.

106.14 Extraordinary Investment by Utility for Extension

Proposed extensions may be reviewed for economic considerations. If the cost of an extension exceeds five times the average embedded cost to serve a customer in the same class as the customer for whom the extension is to be made, the utility may require a contract with the customer. Under the terms of the contract, the customer may be required to pay the recurring estimated operation and maintenance expenses associated with that portion of the extension that is in excess of five times the average embedded cost at the time the extension was made. The reasons and supporting analysis for each contract will be furnished the customer and the Public Service Commission of Wisconsin (Commission), in writing. The utility will inform the customer of the customer's right to ask the Commission for a review of the extension costs and contract provisions. The utility will notify the Commission in writing, when a service extension is denied, including the reasons for denial.

107 INSTALLATION CHARGES AND EMBEDDED COST CREDITS

107.1 Definition of Equipment, Installation Charges and Embedded Cost Credits

For purposes of implementing these installation charges the following definitions shall apply:

107.1a Customer Classifications

Customer classifications are based on usage characteristics. Each classification has a distinct installation charge and embedded cost credit. For definitions of distribution and service facilities installed in new installations see Section 103. Examples of customer classifications are as follows:

- (1.) Residential Service
- (2.) General Service
- (3.) Power Service
- (4.) Street Lighting

Public Service Commission of Wisconsin**EVANSVILLE MUNICIPAL ELECTRIC UTILITY****ELECTRIC RULES****107.1b Total Cost of Installation**

The total cost of an extension shall be defined as the cost of the extension of primary and secondary lines, (excluding the standard meter, the necessary standard service drop or service lateral and individual standard transformer capacity); reconstruction of existing main feeders including changing from single-phase to three-phase or construction of new feeders made necessary solely by addition of such customers; the cost of tree trimming or right of way clearing; securing easements; moving conflicting facilities; and all other costs incident to furnishing service. The customer is responsible for the cost of restoration of the property after the utility has completed installation and backfilling where applicable. This definition applies to both the overhead and underground distribution system. If it is found to be advisable for the utility to install facilities in excess of that required to serve the new customer applying for service, the added cost of these facilities will not be used in determining the cost of the extension.

107.1c Installation Charge

The installation charge is the total cost of installation less the average depreciated embedded cost of the distribution system (excluding cost of the standard transformer and service facilities). Seasonal customers shall receive one-half the average embedded cost allowance of a year-round customer for the same customer classification.

107.1d Average Depreciated Embedded Cost

The embedded cost of the distribution system (excluding the standard transformer and service facilities) is determined by the Public Service Commission for each customer classification, as indicated below. The average depreciated embedded cost by customer classification is listed in Schedule OC-1.

- (1.) **Residential Service:** The average depreciated embedded cost is determined by dividing the original cost less the estimated accrued depreciation of the distribution system and less customer contributions and advances for construction allocated to this customer classification by the number of customers in the group.
- (2.) **Apartment and Rental Units Separately Metered:** The owner of an apartment or rental unit applying for an extension of service shall receive the same average depreciated embedded cost credit, that applies for residential service, per unit metered.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

107.1d Average Depreciated Embedded Cost (continued)

- (3.) Subdividers and Residential Developers: The same average depreciated embedded cost credit, that applies for residential service, would apply per unit energized within five years from the installation of the contributed extension.
- (4.) General Service (Including Multi-Unit Dwellings If Billed on One Meter): The average depreciated embedded cost credit is determined the same way as Residential.
- (5.) Power Service: The embedded allowance is determined by dividing the original cost less the estimated accrued depreciation of the distribution system and less customer contributions and advances for construction allocated to this customer classification by the estimated average billed demand of these customers. When there is an upgrade, the average billed demand is the difference between the averaged billed demand before and after the upgrade.
- (6.) Street Lighting: The dollar amount per fixture is determined by dividing the overall depreciated cost of the distribution facilities allocated to the street lighting class, less credits for past customer contributions and advances for construction, by the total number of lighting fixtures in that classification.

All average depreciated embedded costs (by rate class) shall be subject to review by the Public Service Commission, as part of each general rate case proceeding.

107.2 Total Cost of Installation by Customer Classification

107.2a Residential, General Service, Power Service, and Street Lighting Classes:

Will be charged the total installation cost less the average depreciated embedded cost as defined in Section 107.1d.

107.2b Residential and Commercial Developers and Subdividers:

Residential and Commercial developers and subdividers of single- and two-family subdivisions shall pay, as a minimum, a partially refundable contribution which is the estimated cost of distribution facilities to be installed for the area being developed. The average depreciated embedded cost is refundable as structures are built and connected to the electric utility facilities, as defined in Section 107.1d.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

107.2c Installation Charges for Multi-Family Residential Housing Units:

Will be the total installation cost less the average depreciated embedded cost, as defined in Section 107.1d, per each living unit in the multi-family building.

107.2d Other Installation Charges

In addition to the installation charges provided above, the utility may require the customer to pay, in advance of construction, the estimated direct costs for those distribution service facilities which,

- (1.) Are in excess of standard utility design and construction,
- (2.) Follow a route different than the most direct route as in ch. PSC 113, as determined by the utility, or
- (3.) Require abnormally high installation costs due to abnormal soil conditions, including trenching in rocky soil, frozen ground, or other similar conditions. (Winter construction will normally apply between December 1 and April 1.)

All such payments for these conditions are subject to partial refund as additional customers connect.

107.2e Adjustments to Estimates of the Total Cost of Installation

Section 107.2 explains the method for estimating the total cost of installation. The utility shall adjust its estimate of construction costs to reflect the costs that are actually incurred. Upon completion of an installation which differs from the utility's original cost estimate, a recalculation of the customer contribution shall be made.

108 REFUNDS OF CUSTOMER CONTRIBUTIONS BY TYPE OF CUSTOMER

108.1 Eligibility for Refunds

The utility shall make refunds to a customer who made a contribution for an extension (a contributed extension) when the utility makes an extension from the contributed extension to a second customer which does not require a contribution from the second customer (a non-contributed extension).

In all cases, refunds to the customer making the original contributions shall be limited to the first five years from the installation date. The utility shall make the refund to the customer who made the original contribution or the current property owner of record unless it has a written record from that customer assigning the refund rights to another customer.

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

108.2 Application of the Refund

- (1.) When additional customers are connected to an existing extension, which required an installation charge from the original customer for whom the extension was first made, that original customer may receive a refund from the utility.
- (2.) If the cost of adding a new customer to an existing extension is less than the average depreciated embedded cost, the new customer will be charged nothing. The original contributor of the extension shall be refunded the difference between the average depreciated embedded cost and the cost of adding the new customer.
- (3.) If the cost of additional distribution facilities exceeds the average depreciated embedded cost of a customer classification, the construction will be considered a new extension. In this case no refund is due the original contributor.
- (4.) The original contributor shall receive refunds, if any, for only the first five years from the date the original extension is energized.
- (5.) Refunds shall be made to the original contributing customer by the utility within 20 days after the additional customer's cost of installation is determined.

The amount of the refund shall be based on the embedded cost allowance in effect at the time the contributed extension was installed or the current embedded cost allowance, whichever is greater. In no case shall the total refund exceed the total installation charge.

109 OVERHEAD SERVICE EXTENSIONS

109.1 Applicability

The rules of this section apply to the extension of overhead electric service to all classes of retail customers requesting new service in all areas served by the utility.

The utility will extend electric service to a new customer(s) or existing customer(s) furnished by means of extending its overhead distribution system, except that three-phase service may be furnished by means of phase conversion equipment from a single-phase line.

109.2 Contributions for Overhead Extension

The charge for all overhead extensions shall be the total cost of installation as defined in Section 107.2 less the average depreciated embedded cost (see Section 107.1d).

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

109.3 Combination Single-Phase and Three-Phase Construction

In the event an extension is partially or completely supported on structures used for supporting transmission circuits, or in the event the extension is built to serve both single-phase customers and three-phase customers, the utility will compute, and apportion among the customers served, the extension contribution requirements and contribution refund rights in a fair and equitable manner consistent with the pertinent facts, and will retain in its files a memorandum of such computation and apportionment. The contribution requirement of the single-phase customers shall not be greater than would have been the case if an extension (complying with present engineering standards) had been constructed to only serve single-phase customers.

110 UNDERGROUND SERVICE EXTENSIONS

110.1 General Rules on Underground Service Extensions

The utility will extend utility-standard underground service to all classes of retail customers requesting new service in all areas served by the utility.

110.2 Stipulations on Availability of Underground Service Extensions

Underground service extensions to be furnished by the utility are limited to those which may be placed in locations where grade levels and other conditions are satisfactory to the utility, such as across residential or farm yards or commercial premises or along driveways. The route of the underground construction must be clear of any trees, brush, fences or other surface obstructions that would interfere with normal operation of trenching equipment. Trench backfill shall consist of the original soil and shall not be power tamped. Lawn and landscaping restoration shall be the applicant's responsibility.

Underground service extension in locations such as beneath undeveloped land, quarries, gravel pits, swamps and water will not be furnished except by written approval of the utility for each installation.

The utility will not install an underground service extension where engineering, operating, construction, safety or legal problems would, in the utility's judgment, make it inadvisable to perform the installation, unless these problems can be resolved by the payment of contributions and/or the charges as provided for in these extension rules.

Notification must be given to the utility sufficiently in advance of construction so that a sequence of construction can be provided for and the work coordinated with other utilities involved.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

110.2 Stipulations on Availability of Underground Service Extensions (continued)

If the trench cannot for any reason be dug prior to the freezing of the soil, the utility may temporarily install secondary voltage conductors in suitable mechanical protection on top of the ground and dig the trench when the ground is thawed.

The utility shall not be prevented from installing underground electric equipment where necessary by reason of physical conditions or congestion in the area, when this type of construction is the most economical type for the conditions.

110.3 Contributions for Underground Extensions

The charge for all underground extensions shall be the total cost of the installation as defined in Section 107, less the average depreciated embedded cost as defined in Section 107.1d.

110.4 Contribution for Added Costs Due to Unusual Conditions

For unusual construction costs a contribution is required which may be subject to a partial refund as additional customers attach. The cost shall include:

- (1.) An amount equal to the estimated cost of boring or pavement cutting required or where conductors must be installed in rocky soil, frozen ground, or other similar conditions.
- (2.) An amount equal to the cost of any special requirements such as municipal requirements, rearrangement of facilities due to a change of plans or the need for an underground service extension different from or more elaborate than the utility's standard underground construction.
- (3.) An amount equal to the estimated extra cost of trenching through any area where normal plowing and trenching methods cannot be used (for example, ledge rock, boulders, land-fill, etc.).

Upon completion of the construction, if the actual amount of such extra cost is less than the estimated amount, the utility will refund the difference between the estimated and actual costs.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

110.5 Combination of Overhead and Underground Extension

In accepting an application for underground electric service under this schedule, the utility does not undertake to avoid the construction of overhead lines in the neighborhood, which may be necessary to serve customers who demand and have the right to receive service from overhead lines. However, in order to avoid duplication of facilities, applicants for electric service whose premises can be served from an underground distribution system that has previously been installed adjacent to the applicant's premises shall be required to be served by an underground lateral from such system and shall pay the contributions and charges required in these extension rules.

110.6 Underground Distribution Areas

110.6a General Rules on Underground Distribution Areas

The utility will install utility-standard single-phase underground electric distribution system in accordance with this schedule where required by ordinance or when requested by and agreed to by the property owner(s) or developer or subdivider of the land area to be served. (However, all lines exceeding 15,000 volts in such areas may be overhead.)

Electric distribution facilities provided for under this rule are only for providing service to permanent buildings. The utility will own and maintain the underground conductors and appurtenances, and the character and location of such facilities shall be at the discretion of the utility.

110.6b Establishment of Underground Distribution Areas

(1.) Subdivisions

- a. For purposes of this schedule a subdivision shall be defined as a division of lands consisting of five or more contiguous lots. Lots directly across a street from each other are considered to be contiguous.

- b. To qualify as an underground distribution area the property owner(s) or land developer or subdivider shall have provided a suitable recorded plat of the subdivision with deed restrictions, all satisfactory to the utility, to require all utility service to be supplied by underground lines and prohibiting overhead lines, except for lines exceeding 15,000 volts, and with easements shown.

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

110.6b Establishment of Underground Distribution Areas (continued)

c. An area which qualifies as a subdivision may be established as an underground distribution area in either of the two following ways:

(1) All new subdivisions not already receiving electric service are defined as underground distribution areas where by ordinance the electric distribution systems are required to be underground.

(2) A group of property owners or land developer or subdivider may request that an area be served by an underground distribution system. Such area shall be specifically defined and of reasonably regular shape.

(2.) Mobile Home Courts: A new mobile home court or an expansion of an existing mobile home court, may be established as an under-ground distribution area where:

a. The court consists of five or more established mobile home locations, all of which are contiguous.

b. Occupancy of the mobile homes is to be on a year-round basis.

c. The owner of the mobile home court provides for the utility a written commitment that all utility service will be supplied by underground lines and prohibiting any overhead lines, except for lines exceeding 15,000 volts.

(3.) Condominium Developments and Apartment House Complexes: A new residential condominium development, apartment house complex or an expansion of an existing such housing facility may be established as an underground distribution area where:

a. The condominium or apartment complex consists of five or more dwelling units.

b. The developer provides for the utility a written commitment that all utility service will be supplied by underground lines and prohibiting any overhead lines, except for lines exceeding 15,000 volts.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

110.6b Establishment of Underground Distribution Areas (continued)

- (4.) Easements: The property owner(s) or land developer or subdivider shall have secured for the utility, at no cost to the utility, such easements as the utility may require for the installation, operation and maintenance of its facilities including but not limited to easements for its transformers and switches. The property owner(s) or land developer or subdivider shall inform the utility of any known or expected underground obstructions within the cable routes. Any earth fill added to easements to bring the grade to final level shall not contain any large rocks, boulders, debris or rubbish.

In subdivisions, easements shall be provided along side lot lines as necessary for underground cables to street light locations approved by appropriate governmental authority.

- (5.) Expansion of Underground Distribution Areas: An established underground distribution area may be expanded to include such lots or building sites as are contiguous to it which are not already served by overhead lines. The owners of such lots shall be responsible for seeing that the lots meet the requirements specified above for the underground distribution area to which it is contiguous.

110.6c Contribution and Charges for Extension

- (1.) Contribution for Construction Within Underground Distribution Area: All of the provisions of contributions for construction of underground extensions will apply except that the extension allowance will apply to those lots at which dwelling units are occupied or under construction (construction has proceeded above the foundation level) only. The utility may require that the contribution in aid of construction be paid in advance of construction or may, at the utility's option, offer the property owner(s), land developer or subdivider an installment payment plan.
- (2.) Distribution Line to Underground Distribution Area: Where an extension of the utility's existing distribution system is required in order to reach the underground distribution area, said extension will normally be overhead construction. The extension allowance for the overhead distribution line will apply to those lots on which dwelling units are occupied or under construction (construction beyond the foundation level) only. The utility may require that the contribution in aid of construction be paid in advance of construction or may, at the utility's option, offer customers an installment payment plan. If required by statute or ordinance, or if required by the conditions in the judgment of the utility, all or a portion of the extension will be underground. A refundable contribution as provided in Section 110.6c(1), will apply.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

111 MODIFICATIONS TO EXISTING DISTRIBUTION AND SERVICE FACILITIES

111.1 Relocation and Rebuilding of Existing Distribution Facilities

(1.) Where responsibility can be determined by the utility, the customer responsible for relocation, rebuilding, or other modification of existing distribution facilities shall pay a contribution based on the following:

	Estimated direct cost of new facilities
Less:	Accrued depreciation of facilities to be removed
Less:	Estimated net salvage of the facilities to be removed
Plus:	Estimated cost of removal of existing distribution facilities
Equals:	Charge for modifications to existing facilities

The costs and credits of the above shall be determined from the available records of the utility. The utility shall endeavor to maintain records that permit a reasonable calculation of these costs and credits. The contribution shall be refundable when the extension is less than the embedded allowance as per Section 108, Refunds to Customers.

(2.) Where the utility chooses to relocate its distribution system and it is practicable to bring a service drop or lateral to the existing service entrance facilities, the utility will make the necessary changes in the customer's wiring and service equipment without expense to the customer.

(3.) In the event that the utility is ordered by a unit of government to move its distribution facilities, a new service drop will be installed, where practicable, to the existing service location without expense to the customer. If, in the opinion of the utility, it is not practicable to utilize the existing service entrance facilities, the utility will specify a new service location. The utility is not required to furnish new service entrance, cable, conduct, or service equipment unless it makes a practice of supplying this equipment. The utility shall, however, run a service drop to the nearest point on each building served from the new location and remove the old service drop without expense to the customer.

111.2 Replacement of Overhead Distribution Facilities with Underground Distribution Facilities

A customer requesting the utility to replace existing overhead distribution facilities with underground distribution facilities shall pay the contribution in aid of construction and receive refunds as shown in Section 111.1(1) above.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

111.3 Upgrade of Distribution Facilities Due to Change in Load

Customers who request an upgrading of the utility distribution facilities due to a change in the character of their load shall pay for the construction costs incurred by the utility to provide the requested additional facilities.

- (1) Demand Schedule: Customers who are served under a demand rate schedule shall receive an embedded cost allowance. The kilowatts of demand to be used in determining the allowance shall be the customer's average billed demand after the upgrade less the customer's average billed demand before the upgrade.
- (2) Customers Transferring to a Different Energy-Only Classification: If a customer served under an energy-only sub-classification prior to the upgrade qualifies for a different energy-only sub-classification after the upgrade, the customer shall receive a cost allowance equal to the difference between the two embedded cost allowances.
- (3) Customers Transferring to a Demand Classification: If a customer is served under an energy-only classification prior to the upgrade, the customer shall receive an embedded cost allowance. The kilowatts of demand to be used in determining the allowance shall be the customer's average billed demand after the upgrade less an estimate of the customer's prior average demand.

111.4 Upgrade of Service Facilities

- (1) Overhead Service Drop: The utility shall not charge the customer to upgrade an overhead service drop with a larger size overhead service drop up to the maximum standard size.
- (2) Underground Service Lateral: The utility shall not charge the customer to upgrade an underground service lateral with a larger size underground service lateral up to the maximum standard size.
- (3) Overhead Service Drop to Underground Service Lateral: The utility shall require a contribution from a customer requesting to have an overhead service drop upgraded to an underground service lateral. The contribution shall be equal to the cost of the underground service lateral less the cost of an equivalent overhead service drop.
- (4) Transformers: The utility shall not charge the customers to upgrade their transformer to the maximum standard capacity.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES112 EXTENSION OR MODIFICATION OF TRANSMISSION FACILITIES
TO RETAIL CUSTOMERS

Before a utility extends or modifies its transmission facilities to a retail customer, the utility shall require a contract between the utility and the customer which describes the facilities to be constructed, such as the cost of construction, apportions the responsibility for the construction costs between the utility and the customer, and provides a supporting analysis for the construction and the cost apportionment. The utility shall submit the contract to the Commission for approval. The Commission shall review the contract to assess whether existing ratepayers would be adversely affected by the proposed extension or modification. If the Commission does not respond to the utility within 20 working days from the date of receipt, the contract is approved.

113 TEMPORARY SERVICE

The utility will extend its service to fairs, carnivals and like short-time gatherings and uses (not including short-time uses in the nature of auxiliary, stand-by or seasonal use) under the following rules:

- (1.) The customer will agree to reimburse the utility for its expenditures in extending service.
- (2.) The cost of extending service shall include all items of labor and materials, with the customary overhead charges, necessary to furnish the customer with the service requested. It shall also include any costs involved in the dismantling of materials and their return to stock. Where materials dismantled have a salvage value, the cost of extending service will be credited with such salvage value.
- (3.) All energy will be measured at one standard voltage at some convenient point designated by the utility.
- (4.) The customer will make the necessary arrangements and provide for the necessary equipment in the event more than one voltage is required.
- (5.) The cost of all construction (labor and materials) necessary to distribute energy on the premises occupied by the customer will be borne by the customer.
- (6.) The utility may require the customer to make an advance deposit sufficient to cover the costs of extending service and the estimated bill for energy.
- (7.) The rates applicable in the area where temporary service is rendered shall be applied in determining the customer's bill.

EFFECTIVE: For Service On and After April 1, 1998

PSCW AUTHORIZATION: 1880-ER-103

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

114 TEMPORARY SERVICE FOR CONSTRUCTION

- (1.) The customer will agree to reimburse the utility for its expenditures in extending service.
- (2.) Temporary service shall be given to a customer connection only when constructed in accordance with the sketch as provided by the utility. The post supporting the unit shall be located as near as possible to the location of permanent service to the building. Abnormal conditions involving compliance with the foregoing provision will be cleared with the utility and permission granted by the utility prior to locating the customer connection.
- (3.) All temporary service shall be maintained in a safe manner in order to keep the utility harmless from injury to persons or property. The service shall remain temporary only for a reasonable time and must be made permanent when the utility directs such action.
- (4.) Should the customer elect to receive permanent service the installation charges for extension of new electric service as provided for in Section 107 will apply. Credit shall be given for the payment already made for that portion of the temporary service facilities which can be used for permanent service without modification.

115 EMERGENCY SERVICE

A customer purchasing electric service from the utility under any of the utility's filed rates for firm service, and requesting a reserve line or a separate service connection other than that from which regular service is obtained should consult the utility to determine if such service is available.

The utility may supply emergency service facilities under the terms of a special contract, providing the customer shall pay all costs associated with such facilities. The utility will then provide the emergency service distribution facilities required.

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

116 GENERAL RULES ON CUSTOMER UTILIZATION EQUIPMENT

The rules in this section are designed to assist in maintaining a high standard of electric service for all classes of customers with maximum economy based on electric service rules of the Public Service Commission governing the variation of voltage at customer service entrances.

Before installing any utilization equipment, it shall be the customer's responsibility to notify the utility of the planned addition. The utility will advise customers concerning a specific installation on request. The utility will not test or investigate any customer's equipment except when necessary to determine the cause of substandard voltage conditions. The utility shall, at all reasonable times, have the right to enter a customer's premises to examine the customer's equipment. The utility may refuse to connect service or will suspend service when such equipment does not conform to these rules and it has not been corrected after reasonable notice.

All wiring and other electrical equipment on the premises furnished by the customer shall be installed and maintained by the customer at all times in conformity with the requirements of the Wisconsin State Electrical Code and with the Rules and Regulations of the utility.

Electrical apparatus to be used in connection with and operated by energy furnished by the utility shall be of such design and construction, and installed and operated in such manner, so as not to interfere unreasonably with the utility's service to other consumers. In the event that such apparatus does not comply with the above requirements, the utility may discontinue service until the conditions causing interference with the utility's service to other consumers have been remedied by the customer. The utility may require the installation of a separate power service to serve equipment which does not conform to the rules which govern lighting service or to serve other devices which are likely to interfere with standard voltage regulation.

Where a customer connects single-phase equipment to a three-phase service, the single-phase equipment shall be connected to prevent unbalance of the loads on the three-phase service in excess of 10 percent. A power factor of 90 percent (or as otherwise specified in the company's tariffs) shall be maintained by the customer. When these requirements cannot be met, the customer shall apply for a separate single-phase service.

It shall be the customer's responsibility to install any protective devices such as time-delay under-voltage relays, phase reversal relays, devices to protect against unbalanced phase operation of three-phase equipment and any other device necessary to prevent damage to utilization equipment which might result from imperfections in the supply of power.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

117 MOTORS AND MOTOR CONTROL

In order to prevent impairment of service to other customers, it is necessary to establish limits for the allowable starting currents for motors. Before selecting motor equipment, the customer should consult the utility to determine the specific voltages available at any location.

When a motor is used to drive equipment that requires varying torque during each cycle of operation, such as a compressor or reciprocating pump, the combined installation should have enough momentum in its moving parts so that its operation will not interfere unduly with service to other customers.

- (1.) Types of motor service available on general service lighting rates, single-phase only are as follows:
 - a. Single-phase fractional horsepower motors: Automatically controlled and frequently started, whose locked rotor currents do not exceed 23 amperes may be connected to 120-volt circuits.
 - b. Single-phase motors, one horsepower or less: Manually controlled or infrequently started, whose locked rotor currents do not exceed 50 amperes may be connected to 120-volt circuits. No single-phase motor larger than 1 horsepower shall be operated on a 120-volt circuit.
 - c. Infrequently started single-phase motors of 10 horsepower or less may be connected to 240-volt other circuits if their locked rotor currents do not exceed the values shown in the next section describing motor service available on power rates.
 - d. In urban areas infrequently started three-phase motors of 10 horsepower or less, connected through single-phase to three-phase converters may be used on other circuits.
 - e. Single-phase motors above 10 horsepower are not permitted in rural areas.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

117 MOTORS AND MOTOR CONTROL (continued)

(2.) Types of motor service available on power rates and combined light and power rates, single-phase and three-phase are as follows:

- a. Motors with long periods of continuous operation under maximum load conditions and having not more than four starts per hour may be connected if their locked rotor currents do not exceed those listed in the following table. Consult the utility where these conditions cannot be met, or where equipment ratings and/or starting characteristics exceed the values in the table below:

Motor Starting Table

<u>Motors Rated</u>	<u>Total Locked Rotor Current Not to Exceed</u>
120 Volts, Single-Phase	50 Amperes
240 Volts, Single-Phase 2 Horsepower or Less	60 Amperes
2 to 6.5 Horsepower	60 Amperes Plus 20 Amperes Per Horsepower in Excess of 2 Horsepower
6.5 to 15 Horsepower	150 Amperes Plus 10 Amperes Per Horsepower in Excess of 6.5 Horsepower
240 Volts, Three-Phase 2 Horsepower or Less	50 Amperes
2 to 19.9 Horsepower	50 Amperes Plus 14 Amperes Per Horsepower in Excess of 2 Horsepower
20 to Horsepower	300 Amperes Plus 4 Amperes Per Horsepower in Excess of 20 Horsepower
50 Horsepower and Over	8 Amperes Per Horsepower

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

117 MOTORS AND MOTOR CONTROL (continued)

- b. Motors above 10 horsepower rating are to be three-phase.
- c. New installation of motors of 50 horsepower or larger should be approved by the utility as to motor type, starting and protective equipment, and as to availability of an adequate power supply at the proposed location.
- d. Motors subject to frequent starts, such as elevator and hoist motors, when connected to the secondary distribution system, should have their starting current limited to 100 amperes.
- e. For motors of higher voltage rating than shown in the motor starting table, the allowable currents are inversely proportional to the voltages.

118 MISCELLANEOUS EQUIPMENT

X-ray equipment operated on lighting or combined lighting and power services shall have input currents not exceeding 24 amperes without specific approval of the utility.

All other equipment not specifically provided for in this section will be subject to approval of the utility on the basis of starting currents specified herein for motors with the same frequency of starting. Customers are advised to consult the utility before connecting any such apparatus.

119 PRIVATE POWER PLANTS

No generator may be electrically connected to the utility's lines or equipment without the written consent of the utility and with adequate physical arrangements to prevent hazard to life and damage to utility property.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

119 PRIVATE POWER PLANTS (continued)

After advance written notice and advance approval by the utility, a customer may install his own standby emergency generating equipment and connect it to his wiring systems, provided the connection is through a double-throw switch or other means which will prevent accidental electrical connection of the generator to the utility's facilities at any time. All cost of installation and equipment shall be borne by the customer. The customer shall not operate such equipment until inspection by the utility has been completed. In the event that any customer wishes to engage in parallel operation with the facilities of the utility, service will not be rendered to such customer until a written contract has been entered upon between the customer and the utility and the conditions of delivery of electric energy are fully outlined therein.

Reference Wisconsin Electrical Code.

120 PAYMENT FOR CONTRIBUTION IN AID OF CONSTRUCTION

The utility shall require that the required contribution in aid of construction be paid in advance of construction.

121 STRAY VOLTAGE SERVICE

- (1.) Under normal operating conditions, a neutral-to-earth current or voltage may exist on the grounded or grounding conductors or other conductive objects on the customer's premises. The source of the current or voltage may be located on the premises, off the premises, or a combination of both. Upon the customer's request, the utility will investigate inquiries associated with neutral-to-earth current or voltage concerns.
- (2.) Stray voltage is a 60 Hz steady state AC RMS voltage that can be measured across a 500-ohm shunt resistor which has been connected between two points which livestock may contact simultaneously. "Steady state" means the value of a current or voltage after all transients have decayed to a negligible value. "Transients" mean changes in the steady state current or voltage caused by faults, operation of protective devices, switching, reclosing, tap changing, motor starts or stops, motor stalls or other phenomena that are temporary in nature. The Public Service Commission of Wisconsin (PSCW) has defined the "level of concern" as 1 volt or 2 milliamperes (mA) AC RMS steady state at cow contact.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

- (3.) If a customer requests stray voltage investigative analysis more than two times in a 12-month period, and the utility has not found stray voltage above the level of concern in any of these analyses, the utility may charge a fee for any further stray voltage analyses it performs during the remainder of the 12-month period. The fee may not exceed \$320, which is estimated to be the cost of the additional requested service.
- (4.) Following a determination by the utility that, under normal operating conditions, the contribution to animal contact current from off-farm sources is in excess of 1 mA, the utility shall implement, at its expense, measures to reduce this contribution to below 1.0 mA. For farm facilities housing livestock where stray voltage from off-farm sources is a concern, it may be necessary under certain conditions to modify the farm or utility electrical system, or both.
- (5.) The utility shall, based on a technical and economic analysis of acceptable alternatives for lowering levels of stray voltage at the given location, determine whether long-term system modification should be on-farm, off-farm or both. If the utility, with the consent of the customer, chooses to install a long-term mitigation device (e.g., an electronic grounding system or equipotential plane) on farm property, the customer will assume ownership of the device. The utility will respond to reasonable customer requests regarding maintenance of the device. The customer is responsible for the daily monitoring and energy costs of the on-farm mitigation device, if any. The customer may be required to sign a Stray Voltage Reduction Agreement prior to installation of an on-farm mitigation device.
- (6.) The utility will not install any mitigation device(s) where its stray voltage investigation reveals unsafe conditions, or the inspection report of a state certified commercial electrical inspector or a state certified master electrician reveals that conditions do not comply with applicable electrical codes. If the utility's investigation reveals unsafe conditions, the utility shall notify the customer of the problems found and the potential hazards, and shall recommend the customer take prompt action to remedy the hazard.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

- (7.) In the event modification of on-farm or off-farms systems, to reduce off-farm stray voltage contribution, is not required, the customer may request separation of primary and secondary neutrals. The neutral reconnection device(s) ["isolator(s)"] used for this purpose shall be approved for use by the utility and the PSCW. Prior to installation, the customer shall submit an application form, a satisfactory farm wiring inspection report which has been issued by a state certified commercial electrical inspector or a state certified master electrician, and submit payment for all costs associated with the neutral separation. The customer may be required to sign a Customer Requested Neutral Separation Agreement and may also be required to sign a Hold Harmless/Indemnification Agreement and Release approved by the PSCW. Separation costs shall include labor, equipment, and materials [excluding the isolator(s)] necessary for both isolator(s) installation and a post-separation analysis of possible bypass circuitry. Costs may vary and may, therefore, be subject to a specific determination for each farm location. The isolator(s) shall be owned by the utility and shall be leased to the customer at a lease rate of \$35.00 per isolator, per month. This lease rate includes an appropriate amortized fee to cover the cost of an annual inspection designed to assess isolator effectiveness and to ensure that the isolator(s) continues to perform its intended function of neutral reconnection under fault conditions. Lease agreement shall require monthly billings.
- (8.) If within one year of the date of installation of a customer-requested isolator(s), the customer requests isolator(s) removal, the utility shall refund to the customer all lease amounts which the customer has paid to date.
- (9.) Where modification of on-farm or off-farm systems to reduce off-farm contribution is required but cannot be accomplished within five working days, the utility may install a temporary isolator(s). The customer may be required to sign a Temporary Neutral Separation Agreement prior to installation. The utility must remove the isolator(s) and reconnect the neutrals within 90 days, unless it receives a waiver from the PSCW or the customer completes a Customer Requested Neutral Separation Agreement. Upon receiving a completed Customer Requested Neutral Separation Agreement, the utility (not the customer) will provide the inspection of farm wiring by a state certified master electrician or state certified commercial electrical inspector. If any wiring code violations are found and the customer corrects them within 60 days, the utility will keep the isolator(s) in place. Otherwise, it must remove the isolator(s) and substitute another mitigation technique to reduce off-farm stray voltage to 1.0 mA or less.

Public Service Commission of Wisconsin

EVANSVILLE MUNICIPAL ELECTRIC UTILITY

ELECTRIC RULES

- (10.) Should the customer whose neutrals were temporarily separated as provided for in (9.) above desire the isolator(s) be left in place following the required reduction of off-farm stray voltage contribution, the customer may request the continuation of this service in accordance with the terms and conditions established in (7.) above. The agreement shall be contingent on receipt of a satisfactory wiring inspection report issued by a state certified commercial electrical inspector or a state certified master electrician. Initial installation costs will be waived.
- (11.) At farm locations where primary and secondary neutrals have been separated at the request of the customer as provided for in (7.) and (9.) above, cost-free stray voltage investigative services may be limited to an annual investigation that determines the effectiveness of the isolator and isolation and an analysis of utility facilities only. If on-farm stray voltage analysis or additional determinations of isolation effectiveness are requested by the customer, the Utility may charge a \$320 analysis fee.
- (12.) Numerous locations exist where primary and secondary neutrals have been separated for various reasons prior to the order date, July 16, 1996. As stray voltage investigations are performed at these locations, either at customer request or incident to existing utility isolator removal efforts or system modifications, and the utility's stray voltage contribution under normal operating conditions is determined to be less than 1.0 mA, these customers shall become subject to all of the conditions set forth above.
- (13.) Prior to July 16, 1996, the utilities shall perform the required stray voltage investigation and separate the primary and secondary neutrals within 45 days of the receipt of a PSCW-approved Isolation Request form and a satisfactory farm wiring inspection report which has been issued by a state certified commercial electrical inspector or a state certified master electrician. Subsequent to July 16, 1996, the utilities shall perform the investigation and separation within 30 days of the receipt of the above-referenced documentation. The utility shall not be required to initiate the neutral separation work requested prior to receipt by the utility of full payment for all costs associated with the neutral separation, as specified in (7.) above.
- (14.) The utility may not install, or permit the continued use of, an isolator(s) at locations where livestock are not and/or no longer will be housed.
- (15.) The company may supply service at one point to a customer for distribution by the customer to a number of buildings owned by the customer, provided that such buildings are located on contiguous properties including those directly across public thoroughfares.

SAMPLE
NEUTRAL SEPARATION
AGREEMENTS & CONDITIONS

TEMPORARY NEUTRAL SEPARATION AGREEMENT
Please Read This Carefully!!

The undersigned Customer, _____, an adult residing at and operating a livestock farm located at the address below, agrees to temporary installation of a neutral reconnection device(s) ("isolator(s)") by _____ (the Utility) for the transformer(s) serving the property at:

Address: _____

Mailing Address (if different): _____

C/T/V: _____ State: _____ Zip Code: _____

- A. Temporary isolation is being installed to reduce the Utility's off-farm contribution to below the "level of concern" as defined by docket 05-EI-106 and 05-EI-115.
- B. The isolator(s) will be removed:
 - (1) When the off-farm contribution to stray voltage is less than 1.0 milliampere (voltage measurement of 0.5 volts with a 500-ohm shunt resistor paralleled in the measurement circuit), or
 - (2) Within 90 days of the installation date, unless an extension is granted by the Public Service Commission of Wisconsin (PSCW).
- C. Upon reduction of the Utility's stray voltage contribution to less than 1 mA, the customer shall have the option of leasing the isolator(s) as authorized by the PSCW. In the event the customer chooses to lease the isolator(s), the Utility may require the Customer to sign a Customer Requested Neutral Separation Agreement and/or a PSCW approved Hold Harmless/Indemnification Agreement and Release.

**TEMPORARY NEUTRAL SEPARATION AGREEMENT
GENERAL CONDITIONS**

In addition to the preceding terms and conditions, to which the Customer agrees and accepts, the Customer further understands and agrees to the following:

1. The customer must be the property owner or have the permission of the property owner.
2. That the term stray voltage, as used in this document, is a 60 Hz steady state AC RMS voltage which can be measured at animal contact locations with a 500-ohm shunt resistor paralleled in the measurement circuit.
3. That the isolator(s) of necessity is located near the Utility's transformer(s). The customer has received warning and understands that this location may be hazardous because of its proximity to high voltage equipment. Contact with this high voltage equipment could cause serious injury or death.
4. Acknowledges that the Utility has advised about and explained other available measures that may be implemented to reduce stray voltage levels, which include wiring modifications and equipotential planes.
5. Understands that the isolator(s) not only reduces or prevents stray voltage from utility sources, but will likely diminish stray voltage originating on the Customer's premises. It is also understood that the isolator(s) will not eliminate the sources of stray voltage.
6. Understands the need for the existence and maintenance of proper on-farm wiring and grounding, and the need for regular stray voltage checks. The Customer agrees to timely notify the Utility of any suspected malfunction of the isolator(s).
7. Agrees to allow Utility personnel or their designated representatives access to the farm electrical system and cow contact areas as required to perform testing and/or evaluation.
8. Understands the isolator(s) is owned and maintained by the Utility.
9. Understands that if the Customer has concerns regarding the details of this agreement, the Customer should contact the PSCW at (608) 267-6718.

Customer acknowledges, accepts and agrees to the Terms and General Conditions of this Temporary Neutral Separation Agreement, and agrees to the separation of primary and secondary neutral conductors in accordance herewith.

It is understood and agreed that the terms and conditions of this document are contractual.

PLEASE READ THIS CAREFULLY BEFORE SIGNING!!!

Customer

Date

Property Owner

Date

Utility Representative

Date

CUSTOMER REQUESTED NEUTRAL SEPARATION AGREEMENT
Please Read This Carefully!!!

The undersigned Customer, _____
an adult residing at and operating a livestock farm located at
the address below, request(s) that _____
_____ (the Utility) separate the primary and
secondary neutrals and install a reconnection device(s)
["isolator(s)"] at each transformer providing electric service to
the property at:

Address: _____

Mailing Address (if different): _____

C/T/V: _____ State: _____ Zip Code: _____

- A. The Customer has requested separation of the primary and secondary neutral conductors on the electric service(s) to his/her farm.
- B. The Customer has completed and submitted the Isolation Request form required and approved by the Public Service Commission of Wisconsin (PSCW) and a satisfactory farm wiring inspection report which has been issued by a state certified commercial electrical inspector or a state certified master electrician.
- C. The Customer understands and acknowledges that the results of a stray voltage investigation completed in accordance with PSCW required and approved practices, has indicated that separation of the primary and secondary neutral conductors is not necessary or required.
- D. An isolator(s) will be installed by the Utility following receipt of all costs associated with the installation of the device(s) (excluding the material cost of the isolator), in the amount of \$_____.
- E. The Customer agrees to lease the isolator(s) and finance annual testing of the isolator(s) at a monthly rate of \$35.00, as approved by the PSCW and in accordance with the terms and conditions set forth in this agreement.
- F. The isolator(s) will be removed and the lease agreement will terminate:
 - (1) Upon written request of the Customer.
 - (2) Upon failure of the Customer to pay the agreed upon monthly lease charge.

- G. If the Customer requests the Utility to remove the isolator(s) within one year after installation, the Utility will do so at no cost and will reimburse the Customer for all lease amounts which the customer has paid to date.
- H. The Customer understands and agrees that Utility facilities buried in conjunction with isolator(s) installation will not be removed following termination of the lease agreement.

**CUSTOMER REQUESTED NEUTRAL SEPARATION AGREEMENT
GENERAL CONDITIONS**

In addition to the preceding terms and conditions, to which the Customer agrees and accepts, the Customer further understands and agrees to the following:

1. The requesting customer must be the property owner or have the permission of the property owners.
2. That the term stray voltage, as used in this document, is a 60 Hz steady state AC RMS voltage which can be measured at animal contact locations with a 500-ohm shunt resistor paralleled in the measurement circuit.
3. That the isolator(s) being requested by the Customer of necessity is located near the Utility's transformer(s). The customer has received warning and understands that this location may be hazardous because of its proximity to high voltage equipment. Contact with this high voltage equipment could cause serious injury or death.
4. Acknowledges that the Utility has advised about and explained other available measures that may be implemented to reduce stray voltage levels, which include wiring modification and equipotential planes.
5. Acknowledges and understands that the Utility may require the Customer to sign a PSCW approved Hold Harmless/Indemnification Agreement and Release.
6. Understands that the isolator(s) not only reduces or prevents stray voltage from utility sources, but will likely diminish stray voltage originating on the Customer's premises. It is also understood that the isolator(s) will not eliminate the sources of stray voltage.
7. Understands the need for the existence and maintenance of proper on-farm wiring and grounding, and the need for regular stray voltage checks. The Customer agrees to timely notify the Utility of any suspected malfunction of the isolator(s).
8. Agrees to allow Utility personnel or their designated representatives access to the farm electrical system and cow contact areas as required to perform testing and/or evaluation.
9. Understands the isolator(s) is owned and maintained by the Utility.
10. Understands that if the Customer has concerns regarding the details of this agreement, the Customer should contact the PSCW at (608) 267-6718.

Customer acknowledges, accepts and agrees to the Terms and General Conditions of this Customer Requested Neutral Separation Agreement, and requests the separation of primary and secondary neutral conductors in accordance herewith.

It is understood and agreed that the terms and conditions of this document are contractual.

PLEASE READ THIS CAREFULLY BEFORE SIGNING!!!

Customer

Date

Property Owner

Date

Utility Representative

Date

STRAY VOLTAGE REDUCTION AGREEMENT
Please Read This Carefully!!!

The undersigned Customer, _____
an adult residing at and operating a livestock farm located at
the address below, and _____
_____ (the Utility), agree to make the
modifications listed below to the farm electrical system at:

Address: _____

C/T/V: _____ State: _____ Zip Code: _____

MODIFICATIONS
1. _____
2. _____
3. _____

- A. The above modification(s) will be made at no cost to the customer except as noted:
- _____
- _____
- _____
- B. Materials installed on farm property as a result of the modification(s) will be the property of the Customer.
- C. The Customer agrees to cooperate with the Utility's representative(s) before, during and after modification(s).
- D. The Customer is responsible for the daily monitoring and operating energy costs (if any) of the above modification(s).
- E. The Customer understands that on-farm modifications made by the Utility are permanent.
- F. The Customer understands that the Utility will respond to reasonable requests to perform necessary maintenance of the on-farm modifications.

**STRAY VOLTAGE REDUCTION AGREEMENT
GENERAL CONDITIONS**

In addition to the preceding terms and conditions, to which the Customer agrees and accepts, the Customer further understands and agrees to the following:

1. The requesting customer must be the property owner or have the permission of the property owners.
2. That the term **stray voltage**, as used in this document, is a 60 Hz steady state AC RMS voltage which can be measured at animal contact locations with a 500-ohm shunt resistor paralleled in the measurement circuit.
3. Acknowledges that the Utility has advised about and explained other available measures that may be implemented to reduce **stray voltage** levels.
4. Understands the need for the existence and maintenance of proper on-farm wiring and grounding, and the need for regular **stray voltage** checks.
5. Understands that in the event the Customer suspects that the modifications are not functioning as intended, the Customer agrees to timely notify the Utility.
6. Agrees to allow Utility personnel or their designated representatives access to the farm electrical system and cow contact areas as required to perform testing, evaluation and/or necessary maintenance.
7. Understands that if the Customer has concerns regarding the details of this agreement, the Customer should contact the PSCW at (608) 267-6718.

Customer acknowledges, accepts and agrees to the Terms and General Conditions of this Stray Voltage Reduction Agreement, and agrees to the modification(s) specified herein.

It is understood and agreed that the terms and conditions of this document are contractual.

PLEASE READ THIS CAREFULLY BEFORE SIGNING!!!

Customer

Date

Property Owner

Date

Utility Representative

Date

HOLD HARMLESS/INDEMNIFICATION AGREEMENT AND RELEASE
Please Read This Carefully!!!

AT OUR REQUEST, a neutral reconnection device ("isolator") is being installed between _____ ("the Utility") primary distribution system neutral conductor and the neutral conductor of our secondary electrical service, at our property located at _____ . Our request is made without relying upon any representations made by the Utility or its representatives.

We, for ourselves and all other persons or organizations affiliated with us, agree that the Utility is immune from civil liability for any injury we may sustain that we consider related to the isolation. We also agree to hold the Utility harmless from civil liability for any injury that anyone else claims is related to the isolation.

We have read and understand the terms of this Hold Harmless/Indemnification Agreement and Release. We enter into it voluntarily on behalf of ourselves and all persons and organizations affiliated with us. We understand that the terms of this document are contractual.

Signed this _____ day of _____ 199_, at _____, Wisconsin.

Please Read This Carefully Before Signing!!!

In the presence of _____
(Requesting Customer)

(Requesting Customer)